

	<u>REQUEST FOR INSPECTION (RFI)</u>	
	Major Up-Gradation of Raipur Railway Station of SECR on EPC Mode	

Client : South East Central Railway			Contractor : RPP-SATHYAMOORTHY JV		
RFI No	RFI Date	Type (Regular/Spot)	Name Of the Contractor's Engineer	Item No as per contract (for payment)	Inspection Required On
110/ELE	10-07-2025	Regular	B.K MAHARANA	UTILITIES	11-07-2025

Location / Chainage	33KV SUBSTATION	Name Of the Inspecting Engineer	Inspected On

Description of Work offered for Inspection	CABLE DUCT WORK IN PROGRESS
Enclosures attached with RFI	
Signature of the Contractor's Representative requesting for Inspection	B.K MAHARANA
Remarks of the Inspection Engineer (Representative of Authority Engineer)	The work is in progress. Ensure duct size(500x500)mm.
Signature of the Inspection Engineer Representative of Authority Engineer	Dipak Kumar mahapatra
Date :	11/07/25
Name :	Dipak Kumar Mahapatra

Designation : Resident Engineer Electrical

Remark: CABLE DUCT WORK IN PROGRESS
 Upload Attachment [EE RFI 2 NOS FOR 11.7.25.pdf](#)