
	<b>REQUEST FOR INSPECTION (RFI)</b>	
	<b>Major Up-Gradation of Raipur Railway Station of SECR on EPC Mode</b>	

<b>Client : South East Central Railway</b>			<b>Contractor : RPP-SATHYAMOORTHY JV</b>		
<b>RFI No</b>	<b>RFI Date</b>	<b>Type (Regular/Spot)</b>	<b>Name Of the Contractor's Engineer</b>	<b>Item No as per contract (for payment)</b>	<b>Inspection Required On</b>
227/S&T	02-07-2025	Regular	SHASHI SHARMA	UTILITY SHIFTING OF S&T CABLE	03-07-2025

<b>Location / Chainage</b>	<b>1A BUILDING</b>	<b>Name Of the Inspecting Engineer</b>	<b>Inspected On</b>
		<b>NEERAJ SHUKLA</b>	<b>03-07-2025</b>

<b>Description of Work offered for Inspection</b>	<b>EXCAVATION OF CROSS TRENCH FOR SHIFTING OF EXISTING LIVE S&amp;T CABLE</b>
<b>Enclosures attached with RFI</b>	<b>YES</b>
<b>Signature of the Contractor's Representative requesting for Inspection</b>	<b>SHASHI SHARMA</b>
<b>Remarks of the Inspection Engineer (Representative of Authority Engineer)</b>	<b>WORK IS IN PROGRESS. ENSURE CABLE SAFETY DURING EXCAVATION . JCB IS NOT PERMITTED FOR EXCAVATION WORK.</b>
<b>Signature of the Inspection Engineer Representative of Authority Engineer</b>	<b>NEERAJ SHUKLA</b>
<b>Date :</b>	<b>03/07/25</b>
<b>Name :</b>	<b>Archishman Banerjee</b>

**Designation : Resident Engineer Signalling and Telecom**

Remark:

Upload Attachment [RFI 03-07-25 s&t.pdf](#)