

	<b><u>REQUEST FOR INSPECTION (RFI)</u></b>	
	<b>Major Up-Gradation of Raipur Railway Station of SECR on EPC Mode</b>	

Client : South East Central Railway			Contractor : RPP-SATHYAMOORTHY JV		
RFI No	RFI Date	Type (Regular/Spot)	Name Of the Contractor's Engineer	Item No as per contract (for payment)	Inspection Required On
111/ELE	10-07-2025	Regular	B.K MAHARANA	UTILITIES	11-07-2025

Location / Chainage	19 C BUILDING AREA	Name Of the Inspecting Engineer	Inspected On

Description of Work offered for Inspection	HT CABLE END TERMINATION BOTH SIDE FROM 33KV SUBSTATION AND DP STRUCTURE NEAR RUNNING ROOM.
Enclosures attached with RFI	
Signature of the Contractor's Representative requesting for Inspection	B.K MAHARANA
Remarks of the Inspection Engineer (Representative of Authority Engineer)	End termination is not advised in rainy weather
Signature of the Inspection Engineer Representative of Authority Engineer	Dipak Kumar mahapatra
Date :	11/07/25
Name :	Dipak Kumar Mahapatra

**Designation : Resident Engineer Electrical**

Remark: HT CABLE END TERMINATION BOTH SIDE FROM 33KV SUBSTATION AND DP STRUCTURE NEAR RUNNING ROOM.

Upload Attachment [EE RFI 2 NOS FOR 11.7.25.pdf](#)