

	<u>REQUEST FOR INSPECTION (RFI)</u>	
	Major Up-Gradation of Raipur Railway Station of SECR on EPC Mode	

Client : South East Central Railway			Contractor : RPP-SATHYAMOORTHY JV		
RFI No	RFI Date	Type (Regular/Spot)	Name Of the Contractor's Engineer	Item No as per contract (for payment)	Inspection Required On
PL/254	22-08-2025	Regular	JAVED ANSARI	S.W.R PIPE LAYING & MANUAL EXCAVATION	23-08-2025

Location / Chainage	TEMPORARY PARCEL OFFICE	Name Of the Inspecting Engineer	Inspected On
		HARSHAD PATEL	23-08-2025

Description of Work offered for Inspection	CHECKING FOR MANUAL EXCAVATION & S.W.R PIPE LAYING AT TEMPORARY PARCEL OFFICE
Enclosures attached with RFI	
Signature of the Contractor's Representative requesting for Inspection	JAVED ANSARI
Remarks of the Inspection Engineer (Representative of Authority Engineer)	Work is in progress. During the laying maintain proper slope of the pipe line.
Signature of the Inspection Engineer Representative of Authority Engineer	
Date :	23/08/25
Name :	HARSHAD PATEL

Designation : SENIOR MANAGER MEP

Remark: CHECKING FOR MANUAL EXCAVATION & S.W.R PIPE LAYING FOR TEMPORARY PARCEL OFFICE
 Upload Attachment [PL 254.pdf](#)