

	<b><u>REQUEST FOR INSPECTION (RFI)</u></b>	
	<b>Major Up-Gradation of Raipur Railway Station of SECR on EPC Mode</b>	

Client : South East Central Railway			Contractor : RPP-SATHYAMOORTHY JV		
RFI No	RFI Date	Type (Regular/Spot)	Name Of the Contractor's Engineer	Item No as per contract (for payment)	Inspection Required On
215/ELE	13-07-2025	Regular	B.K MAHARANA	HT CABLE CHARGING	14-07-2025

Location / Chainage	19C BUILDING	Name Of the Inspecting Engineer	Inspected On
		Dipak Kumar mahapatra	14-07-2025

Description of Work offered for Inspection	CHECKING OF HT CABLE CHARGING FOR 19C AT 33KV SUBSTATION
Enclosures attached with RFI	yes
Signature of the Contractor's Representative requesting for Inspection	B.K MAHARANA
Remarks of the Inspection Engineer (Representative of Authority Engineer)	Meggering of HT cable conducted and found satisfactory. Charging of the same will be done after due permission from open line.
Signature of the Inspection Engineer Representative of Authority Engineer	
Date :	14/07/25
Name :	Dipak Kumar Mahapatra

**Designation : Resident Engineer Electrical**

Remark: CHECKING OF HT CABLE CHARGING FOR 19C AT 33KV SUBSTATION

Upload Attachment [ELE RFI TODAY.jpg](#)