

	<u>REQUEST FOR INSPECTION (RFI)</u>	
	Major Up-Gradaation of Raipur Railway Station of SECR on EPC Mode	

Client : South East Central Railway			Contractor : RPP-SATHYAMOORTHY JV		
RFI No	RFI Date	Type (Regular/Spot)	Name Of the Contractor's Engineer	Item No as per contract (for payment)	Inspection Required On
PL/259	18-09-2025	Regular	ANOSH KUMAR	EXCAVATION & MAKING OF BIO SEPTIC TANK	19-09-2025

Location / Chainage	GRP OFFICE (PLATFORM NO.01)	Name Of the Inspecting Engineer	Inspected On
		HARSHAD PATEL	20-09-2025

Description of Work offered for Inspection	CHECKING FOR EXCAVATION & MAKING OF BIO SEPTIC TANK
Enclosures attached with RFI	
Signature of the Contractor's Representative requesting for Inspection	ANOSH KUMAR
Remarks of the Inspection Engineer (Representative of Authority Engineer)	Manually excavation permission only allowed on the platform area. Use cable fault locator for the find out the cable.
Signature of the Inspection Engineer Representative of Authority Engineer	
Date :	20/09/25
Name :	HARSHAD PATEL

Designation : SENIOR MANAGER MEP

Remark: CHECKING FOR EXCAVATION & MAKING OF BIO SEPTIC TANK

Upload Attachment [PL 259.jpg](#)