

	<b>REQUEST FOR INSPECTION (RFI)</b>	
	<b>Major Up-Gradation of Raipur Railway Station of SECR on EPC Mode</b>	

<b>Client : South East Central Railway</b>			<b>Contractor : RPP-SATHYAMOORTHY JV</b>		
<b>RFI No</b>	<b>RFI Date</b>	<b>Type (Regular/Spot)</b>	<b>Name Of the Contractor's Engineer</b>	<b>Item No as per contract (for payment)</b>	<b>Inspection Required On</b>
109/ELE	08-07-2025	Regular	B.K.MAHARANA	UTILITY SHIFTING	09-07-2025

<b>Location / Chainage</b>	<b>HT CABLE END TERMINATION WORK AT 19 C</b>	<b>Name Of the Inspecting Engineer</b>	<b>Inspected On</b>
		Tukaram Sahu	09-07-2025

<b>Description of Work offered for Inspection</b>	<b>33 KV SUBSTATION &amp; DP STRUCTURE NEAR RUNNING ROOM HT CABLE END TERMINATION WORK</b>
<b>Enclosures attached with RFI</b>	yes
<b>Signature of the Contractor's Representative requesting for Inspection</b>	<b>B.K.MAHARANA</b>
<b>Remarks of the Inspection Engineer (Representative of Authority Engineer)</b>	<b>Erection of end termination kit not permissible in rainy weather.</b>
<b>Signature of the Inspection Engineer Representative of Authority Engineer</b>	<b>Tukaram Sahu</b>
<b>Date :</b>	<b>09/07/25</b>
<b>Name :</b>	<b>Dipak Kumar Mahapatra</b>

**Designation : Resident Engineer Electrical**

Remark: 33 KV SUBSTATION & DP STRUCTURE NEAR RUNNING ROOM HT CABLE END TERMINATION WORK

Upload Attachment [RFI 109 ELE.pdf](#)