



XHEZC.SP986 Firestop Systems

[Page Bottom](#)

Firestop Systems

[See General Information for Firestop Systems](#)


System No. SP986

May 20, 2004

(For Vertical Separations)

F and FH Rating — 1 and 2 h (See item 1)

FT and FTH Rating — 0 h



1. **Wall Assembly** — The 1 or 2 h fire-rated gypsum wallboard/stud wall assembly shall be constructed of the materials and in the manner specified in the individual Wall or Partition designs in the Underwriters' Laboratories' Laboratories of Canada List of Equipment and Materials and shall include the following construction features:

(a) **Studs** — Wall framing may consist of either wood studs or steel channel studs. Wood studs to consist of nominal 50 mm by 102 mm lumber spaced 405 mm OC. Steel studs to be minimum 92 mm wide and spaced maximum 600 mm OC.

(b) **Wallboard, Gypsum** — Nominal 16 mm thick, 1220 mm wide, with square or tapered edges. The gypsum wallboard type, number of layers, fastener type and sheet orientation shall be as specified in the individual wall or partition design. Maximum size of opening is 1016 mm by 508 mm.

The hourly F and FH ratings of the firestop system are equal to the hourly fire rating of the wall assembly in which it is installed.

2. **Duct** — Maximum 457 mm by 965 mm galvanized steel duct, 0.71 mm in thickness. Maximum separation of 51 mm between duct and periphery of opening. Duct to be rigidly supported on both sides of the wall.

3. **Steel Angle** —

(a). Nominal 75 mm by 50 mm by 1.5 mm steel angle installed on the two faces of the duct separated from drywall using sheet metal screws between the 50 mm leg of the angle and the duct, installed a maximum of 110 mm OC.

(b). Nominal 50 mm by 25 mm by 1.5 mm steel angle installed on the two faces of the duct in contact with the drywall, using sheet metal screws between the 50 mm leg of the angle and the duct, installed a maximum of 110 mm OC.

■ 4. **Firestop System Components** — (XHJZC). Type "A/D FIREBARRIER Silicone Sealant" installed with 6.4 mm bead on each leg of steel angle and compressed between angle and duct and angle and drywall. Additional 6.4 mm bead of sealant installed as crown bead between duct and wall at point of contact.

A/D FIRE PROTECTION SYSTEMS INC

Last Updated on 2004-05-20

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

Copyright © 2016 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2016 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

