System No. F-E-1022
XHEZ7.F-E-1022
Through-penetration Firestop Systems Certified for Canada

Page Bottom

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

XHEZ - Through-penetration Firestop Systems

XHEZ7 - Through-penetration Firestop Systems Certified for Canada

See General Information for Through-penetration Firestop Systems

See General Information for Through-penetration Firestop Systems Certified for Canada

System No. F-E-1022

June 14, 2016

ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating — 1 Hr	F Rating — 1 Hr
T Rating — 3/4 Hr	FT Rating —3/4 Hr
	FH Rating — 1 Hr
	FTH Rating —3/4 Hr



SECTION A-A

1. **Floor-Ceiling Assembly —** The 1 hr fire-rated concrete and steel joist Floor-Ceiling assembly shall be constructed of the materials and in the manner described in the individual G500 Series Design in the UL Fire Resistance Directory, as summarized below:

A. **Concrete Floor —** Normal weight or lightweight (100-150 pcf (1601-2402 kg/m^3)) concrete over metal lath or steel deck as specified in the individual G500 Series Design. Max diam of floor opening is 3-3/16 in (81 mm).

B. **Joists —** Steel joists or Structural Steel Members* as specified in the individual G500 Series Design.

C. **Gypsum Board* —** Min 5/8 in. (16 mm) thick, screw-attached to furring channels as specified in the individual G500 Series Design. Max diam of ceiling opening is 3-3/16 in (81 mm).

2. **Through Penetrating Products* —** Flexible Metal Piping Nom 2 in. (51 mm) diam (or smaller) steel Flexible Metal Piping to be installed either concentrically or eccentrically within the firestop system. The space between pipe and periphery of opening shall be min 0 (point contact) to max 7/8 in (0 to 22 mm). Pipe to be rigidly supported on both sides of floor assembly. Plastic covering on piping shall be removed for a distance of 2 ft (610 mm) on both sides of the floor.

OMEGA FLEX INC

3. **Firestop System —** The firestop system shall consist of the following:

A. **Packing Material —** (Optional) - Foam backer rod firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor and bottom surface of the ceiling as required to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material* - (Caulk) —** Min 1/2 in. (13 mm) thickness of fill material applied within the annulus, flush with top surface of the floor and bottom surface of the ceiling. Additional fill material to be installed such that a min 1/16 in. (2 mm) crown is formed around the penetrating item and lapping 3/8 in. (10 mm) beyond the periphery of the opening.

A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Intumescent Sealant, A/D FIREBARRIER Intumescent Sealant II

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2016-06-14