



XHEZC.JF51 Firestop Systems

[Page Bottom](#)

Firestop Systems

[See General Information for Firestop Systems](#)

System No. JF51


October 27, 2006

(For Horizontal or Vertical Separations)

F Rating — 4 h

FT, FH and FTH Ratings — 0 h

Joint Not Evaluated For Movement Capability



1. **Floor or Wall** — Normal-density ($2400 \pm 50 \text{ kg/m}^3$) concrete. Maximum width of opening 200 mm. Minimum depth of concrete floor or wall 114 mm.

2. **Firestop System Components** — (XHJZC). "A/D FIREBARRIER Mineral Wool" insulation installed in one or two width layers. Uncompressed width of insulation to be 33% wider than width of opening to be filled. End joints to be firmly butted. Depth of insulation to be 102 mm minimum.

A/D FIRE PROTECTION SYSTEMS INC

3. **Firestop System Components** — (optional) - (XHJZC).

For horizontal separations, "A/D FIREBARRIER Silicone Sealant", or "A/D FIREBARRIER Silicone Sealant SL" may be applied over insulation (Item 2) to a minimum thickness of 6.4 mm, or "A/D FIREBARRIER Seal" or "A/D FIREBARRIER

Seal NS" may be applied over insulation (Item 2) to a minimum wet thickness of 5 mm.

For vertical separations, "A/D FIREBARRIER Silicone Sealant" may be applied over insulation (Item 2) on both sides of assembly to a minimum thickness of 6.4 mm, or "A/D FIREBARRIER Seal NS" may be applied over insulation (Item 2) to a minimum wet thickness of 5 mm.

A/D FIRE PROTECTION SYSTEMS INC

Last Updated on 2006-10-27

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

Copyright © 2016 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2016 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

