System No. W-J-1085
XHEZ7.W-J-1085
Through-penetration Firestop Systems Certified for Canada

Page Bottom

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

XHEZ7 - Through-penetration Firestop Systems Certified for Canada

See General Information for Through-penetration Firestop Systems Certified for Canada

System No. W-J-1085

October 26, 2011

F Rating — 2 Hr

FT Rating — 0 Hr

FH Rating — 2 Hr

FTH Rating — 0 Hr



SECTION A-A

1. **Wall Assembly —** Min 6 in. thick reinforced lightweight or normal weight (100-150 pcf) concrete. Wall may also be constructed of any UL Classified **Concrete Blocks***. Max diam of opening is 4 in.

See **Concrete Blocks** (CAZT) category in the Fire Resistance Directory for names of manufacturers.

2. **Through Penetrant —** One metallic pipe, tubing or conduit to be installed either concentrically or eccentrically within the firestop system. The annular space between pipes, tubing or conduits and periphery of opening shall be min 0 in. (point contact) to max 1-7/8 in. Pipe, tubing or conduit to be rigidly supported on both sides of wall assembly. The following types and sizes of metallic pipes, tubing or conduits may be used:

A. **Steel Pipe —** Nom 2 in. diam (or smaller) Schedule 10 (or heavier) steel pipe.

B. **Iron Pipe —** Nom 2 in. diam (or smaller) cast or ductile iron pipe.

C. **Copper Tubing —** Nom 2 in. diam (or smaller) Type L (or heavier) copper tubing.

D. **Copper Pipe —** Nom 2 in. diam (or smaller) Regular (or heavier) copper pipe.

E. **Conduit —** Nom 2 in. diam (or smaller) steel electrical metallic tubing or galv steel conduit.

3. **Fill, Void or cavity Material*Sealant —** Min 5/8 in. thickness of fill material applied within annulus, flush with both surfaces of wall. At the point contact location between through penetrant and concrete, a min 3/8 in. diam bead of fill material shall be applied at the concrete/through penetrant interface on both surfaces of wall.

A/D FIRE PROTECTION SYSTEMS INC — A/D FireBarrier Silicone

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2011-10-26