

F Rating — 3 Hr
T Rating — 0 Hr



- E. Copper Pipe** Nom 3 in. dia. (or smaller) Regular (or heavier) copper pipe.

C-AJ-1116 continued...

4. Firestop System The firestop system shall consist of the following:

A. Packing Material Min 4 in. thickness of min 4 pcf mineral wool batt insulation firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor or from both surfaces of wall as required to accommodate the required thickness of fill material. When the floor is constructed of hollow-core precast concrete units, packing material shall be recessed from both surfaces of floor to accommodate the required thickness of fill material.

B. Fill, Void or Cavity Material* — Caulk Min 1/2 in. thickness of fill material applied within the annulus, flush with top surface of floor or with both surfaces of wall. When the floor is constructed of hollow-core precast concrete units, fill material shall be installed symmetrically on both sides of floor, flush with both floor surfaces.

A/D FIRE PROTECTION SYSTEMS INC — A/D Silicone Firebarrier Sealant [S/L (floors only) or G/G (floor, hollow-core precast concrete units or walls)].

*Bearing the UL Classification Mark