



System No. FW-S-0007
XHBN.FW-S-0007
Joint Systems

[Page Bottom](#)

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
 - Authorities Having Jurisdiction should be consulted before construction.
 - Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
 - When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
 - Only products which bear UL's Mark are considered Certified.
-

XHBN - Joint Systems


[See General Information for Joint Systems](#)

System No. FW-S-0007

February 17, 2005

Assembly Rating - 1 Hr

Joint Width — 1 in. Max.



1. **Wall Assembly** — Min 4-1/2 in. thick reinforced lightweight or normal weight (100-150 pcf) structural concrete. Wall may also be constructed of any UL Classified **Concrete Blocks***.

See **Concrete Blocks** (CAZT) category in the Fire Resistance Directory for names of manufacturers.

2. **Floor Assembly** — Min 4-1/2 in. thick reinforced lightweight or normal weight (100-150 pcf) structural concrete.

3. **Joint System** — Max width of joint is 1 in. The joint system shall consist of the following:

A. **Membranes*** — (Optional) - Min 5-1/2 in. width of membrane applied to either inside surface of joint, flush with bottom of joint and extending a min of 1 in. on wall surface above joint or overlapping min 1 in. onto top surface of floor. Each adjoining length of membrane shall overlap previous length by 2 in. Prior to application of membrane, Blueskin Primer applied to concrete surface at a min application rate of 0.04 psf.

HENRY COMPANY L L C — Blueskin SA and SA-LT

B. **Packing Material** — Min 1 in. diam. open or closed cell polyurethane foam backer rod used as a form to prevent the leakage of the fill material. Packing material to be recessed from top surface of floor as required to accommodate the required thickness of fill material.

C. **Fill, Void or Cavity Material*** — Min 1 in. thickness of fill material applied within the joint, flush with top surface of floor.

A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Silicone or Silicone S/L

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Last Updated on 2005-02-17

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".