

XHEZC.SP880 Firestop Systems

Page Bottom

Firestop Systems

See General Information for Firestop Systems


System No. SP880

October 04, 2005

(For Horizontal or Vertical Separations)

F and FH Ratings — 3 h

FT and FTH Ratings - 0 h



- 1. **Floor or Wall Assembly** Minimum 115 mm thick reinforced low-density or normal-density (1600 2400 kg/m³) concrete. Floor may also be constructed of minimum 152 mm thick hollow-core precast concrete units having a fire resistance rating equal to or greater than that of the firestop system. Wall may also be constructed of nominal 200 mm thick concrete block. Maximum diameter of opening is 28 mm larger than diameter of through-penetrant (Item 2). When precast concrete units are used, maximum diameter of opening is 178 mm.
- 2. **Pipes or Conduits** One metallic pipe, conduit or tubing to be installed within the firestop system. Pipe, conduit or tubing to be rigidly supported on both sides of floor or wall assembly. The annular space shall be 0 mm (point contact) to maximum 28 mm. The following types and sizes of pipes, conduits or tubing may be used:
 - (a) Steel Pipe Nominal 610 mm diameter (or smaller) Schedule 10 (or heavier) steel pipe.

- (b) Iron Pipe Nominal 610 mm diameter (or smaller) cast or ductile iron pipe.
- (c) **Conduit** Nominal 152 mm diameter (or smaller) steel electrical metallic tubing or steel conduit
- (d) **Copper Pipe or Tubing** Nominal 152 mm diameter (or smaller) Type L (or heavier) copper tubing.
- 3. Firestop System Components (XHJZC).
 - (a) **Batts and Blankets** Type "A/D FIREBARRIER Mineral Wool" compressed 33% and installed within the opening to a minimum depth of 100 mm and recessed 13 mm from top surface of slab or both sides of wall. and hollow-core precast concrete floor.
 - (b) **Sealants** Type "A/D FIREBARRIER Silicone Sealant", caulk grade sealant applied to the top of mineral wool insulation to a minimum depth of 13 mm. In floors constructed of hollow-core precast concrete units, sealant installed symmetrically on both sides of floor. Additional material installed to form a crown of minimum 13 mm at point contact where the pipe contacts the edge of opening. For vertical installations, sealant to be applied symmetrically on both sides of wall.

OR

(c) **Sealants** — Type "A/D FIREBARRIER Silicone Sealant SL", for horizontal installations only (with the exception of hollow-core precast concrete units), applied to the top of mineral wool insulation to a minimum depth of 13 mm. Additional caulk grade material (Item 3b) installed to form a crown of minimum 13 mm at point contact where the pipe contacts the edge of opening.

A/D FIRE PROTECTION SYSTEMS INC

Last Updated on 2005-10-04

<u>Questions?</u> <u>Print this page</u> <u>Terms of Use</u> <u>Page Top</u>

Copyright © 2016 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the <u>UL Environment</u> database for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2016 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

