



System No. FF-S-0039
XHBN7.FF-S-0039
Joint Systems Certified for Canada

[Page Bottom](#)

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

XHBN - Joint Systems

XHBN7 - Joint Systems Certified for Canada


[See General Information for Joint Systems](#)

[See General Information for Joint Systems Certified for Canada](#)

System No. FF-S-0039

June 13, 2016

| ANSI/UL2079 | CAN/ULC S115 |
|--|--|
| Assembly Rating — 2 Hr | F Rating — 2 Hr |
| Nominal Joint Width — 2 In. Maximum | FT Rating — 2 Hr |
| L Rating At Ambient — Less Than 1 CFM/Lin Ft | FH Rating — 2 Hr |
| L Rating At 400°F — Less Than 1 CFM/Lin Ft | FTH Rating — 2 Hr |
| | Nominal Joint Width — 51 mm Maximum |
| | L Rating At Ambient — Less Than 1.55 L/s/m |
| | L Rating At 400°F — Less Than 1.55 L/s/m |



1. **Floor Assembly** — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m²) structural concrete.

2. **Joint System** — Max width of joint is 2 in. (51 mm). The joint system shall consist of the following:

A. **Packing Material** — Min 4 in. (102 mm) thickness of min 2.5 pcf (40 kg/m³) mineral wool batt insulation firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor as required to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material*** — Min 1/2 in. (51 mm) wet thickness of fill material applied within the joint, flush with top surface of floor.

A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Acrylic Sealant

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2016-06-13

Questions?

Print this page

Terms of Use

Page Top

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".