


**System No. F-C-7067****XHEZ7.F-C-7067****Through-penetration Firestop Systems Certified for Canada**[Page Bottom](#)**Design/System/Construction/Assembly Usage Disclaimer**

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

**XHEZ - Through-penetration Firestop Systems****XHEZ7 - Through-penetration Firestop Systems Certified for Canada**[See General Information for Through-penetration Firestop Systems](#)[See General Information for Through-penetration Firestop Systems Certified for Canada](#)**System No. F-C-7067**

June 01, 2016

ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating - 1 Hr	F Rating - 1 Hr
T Rating - 1/2 Hr	FT Rating - 1/2 Hr
	FH Rating - 1 Hr
	FTH Rating - 1/2 Hr



1. **Floor-Ceiling Assembly** — The 1 hr fire-rated solid or trussed lumber joist floor-ceiling assembly shall be constructed of the materials and in the manner specified in the individual L500 Series Floor-Ceiling Designs in the UL

Fire Resistance Directory. The general construction features of the floor-ceiling assembly are summarized below:

A. **Flooring System** — Lumber or plywood subfloor with finish floor of lumber, plywood or **Floor Topping Mixture\*** as specified in the individual Floor-Ceiling Design. Max diam of floor opening is 11 in. (279 mm).

B. **Wood Joists\*** — Nom 10 in. (254 mm) deep (or deeper) lumber, steel or combination lumber and steel joists, trusses or **Structural Wood Members\*** with bridging as required and with ends firestopped.

C. **Gypsum Board\*** — Nom 4 ft wide by 5/8 in. (16 mm) thick as specified in the individual Floor-Ceiling Design.. Max diam of ceiling opening is 11 in. (279 mm).

2. **Steel Duct** — Max 10 in. (254 mm) diam. No. 30 ga. (or heavier) galv steel duct to be installed either concentrically or eccentrically within the firestop system. The space between the steel duct and periphery of opening shall be min 0 in. (point contact) to max 1 in. (25 mm). Steel duct to be rigidly supported on both sides of the floor-ceiling assembly.

3. **Forming Material** — (Optional) — Foam backer material firmly packed into opening as a permanent form. Forming material to be recessed from top surface of floor or sole plate and bottom surface of ceiling or lower top plate of chase wall assembly as required to accommodate the required thickness of fill material.

4. **Firestop System** — Min 1/2 in. (13 mm) thickness of sealant applied within the annulus flush with the top surface of the floor. Min 3/8 in. (10 mm) thickness of sealant applied within the annulus flush with the bottom surface of gypsum board ceiling.

**A/D FIRE PROTECTION SYSTEMS INC** — A/D FIREBARRIER Intumescent Sealant or A/D FIREBARRIER Intumescent Sealant II

**\* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2016-06-01

---

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".