



System No. C-AJ-8029 XHEZ.C-AJ-8029 Through-penetration Firestop Systems

[Page Bottom](#)

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

XHEZ - Through-penetration Firestop Systems


[See General Information for Through-penetration Firestop Systems](#)

System No. C-AJ-8029

December 09, 1997

F Rating — 3 Hr

T Rating — 0 Hr



1. **Floor or Wall Assembly** — Min 4-1/2 in. thick reinforced normal weight (140-150 pcf) concrete. Wall may also be constructed of any UL Classified **Concrete Blocks***. Floor may also be constructed of any min 8 in. thick UL Classified hollow core **Precast Concrete Units***. Max area of opening is 312 sq in. with max dimension of 28 in. If the firestop system is installed within a hollow-core precast concrete unit, the max area of opening is 49 sq in. with max dimension of 7 in.

See **Concrete Blocks** (CAZT) and **Precast Concrete Units** (CFTV) categories in the Fire Resistance Directory for names of manufacturers.

2. **Cable Tray*** — Max 24 in. wide by max 4 in. deep open ladder cable tray with channel-shaped side rails formed of min 0.065 in. thick steel with 3 in. wide by 1/2 in. deep rungs spaced 14-1/2 in. OC. One cable tray to be installed in the

opening. The annular space between the cable tray and the periphery of the opening shall be min 1 in. to max 6 in. Cable tray to be rigidly supported on both sides of floor or wall assembly.

3. **Cables** — Aggregate cross-sectional area of cables in cable tray to be max 40 percent of the cross sectional area of the tray based on a max 3 in. cable loading depth within the cable tray. Any combination of the following types of copper conductor cables may be used:

- A. Max 1/C-500 kcmil (or smaller) cable with cross-linked polyethylene insulation and jacket.
- B. Max of 100 pair No. 24 AWG telephone cable with polyvinyl chloride (PVC) insulation and jacket.
- C. Max RG 11/U coaxial cable (or smaller) with fluorinated ethylene propylene insulation and jacket.
- D. Max 2/C-No. 12 AWG (or smaller) cable with (PVC) insulation and jacket.

In addition, a max of two cables may be installed outside the cable tray. The cables shall be spaced a nom 2 in. apart and a nom 2 in. from the periphery of the opening. The cable shall be spaced a min 2 in. to max 4 in. from the other through penetrants (Item Nos. 2, 4 and 5). Cables to be rigidly supported on both sides of floor or wall assembly.

4. **Through-Penetrants** — Two pipes, conduits or tubes to be installed within the opening. The space between pipes, conduits or tubes shall be a nom 6-3/4 in. The space between pipes, conduits or tubes and periphery of opening shall be min 1-1/2 in. to max 6-1/2 in. Pipes, conduits or tubes shall be spaced a min 2 in. to a max 4 in. from the other through penetrants (Item Nos. 2, 3 and 5). Pipes, conduits or tubes to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of metallic pipes, conduits or tubes may be used:

- A. **Steel Pipe** — Nom 3 in. diam (or smaller) Schedule 40 (or heavier) steel pipe.
- B. **Iron Pipe** — Nom 3 in. diam (or smaller) cast or ductile iron pipe.
- C. **Conduit** — Nom 3 in. diam (or smaller), steel electrical metallic tubing or steel conduit.
- D. **Copper Tubing** — Nom 3 in. diam (or smaller) Type M (or heavier) copper tubing.
- E. **Copper Pipe** — Nom 3 in. diam (or smaller) Regular (or heavier) copper pipe.

In addition, one nom 2 in. diam (or smaller) steel electrical metallic tubing or steel conduit may be installed within the cable tray (Item 2). The conduit or tubes shall be spaced a nom 1 in. from the side rail of the cable tray and a min 1 in. from the cable bundles.

5. **Pipe Covering*** — The following types of pipe coverings may be used on the steel pipe (Item 4A):

A. **Pipe and Equipment Covering — Materials*** — Nom 1 in. thick hollow cylindrical heavy density (min 3.5 pcf) glass fiber units jacketed on the outside with an all service jacket. Longitudinal joints sealed with metal fasteners or factory-applied self-sealing lap tape. Transverse joints secured with metal fasteners or with butt tape supplied with the product.

See **Pipe and Equipment Covering — Materials** (BRGU) category in the Building Materials Directory for names of manufacturers. Any pipe covering material meeting the above specifications and bearing the UL Classification Marking with a Flame Spread Index of 25 or less and a Smoke Developed Index of 50 or less may be used.

B. **Pipe Covering Materials*** — Nom 1 in. thick unfaced mineral fiber pipe insulation having a nom density of 3.5 pcf (or heavier) and sized to the outside diam of pipe or tube. Pipe insulation secured with min 8 AWG steel wire spaced max 12 in. OC.

INDUSTRIAL INSULATION GROUP L L C — High Temperature Pipe Insulation 1200, High Temperature Pipe Insulation BWT or High Temperature Pipe Insulation Thermaloc

C. **Sheathing Material*** — (Not Shown) — Used in conjunction with Item 5B. Foil-scrim-kraft or all service jacket material shall be wrapped around the outer circumference of the pipe insulation (Item 3B) with the kraft side exposed. Longitudinal joints and transverse joints sealed with metal fasteners or with butt tape.

See **Sheathing Materials** (BVDV) category in the Building Materials Directory for names of manufacturers. Any sheathing material meeting the above specifications and bearing the UL Classification Marking with a Flame Spread Index of 25 or less and a Smoke Developed Index of 50 or less may be used.

The space between the insulated pipe and the periphery of the opening shall be a min 1-1/2 in. to a max 6-1/2 in. The insulated pipe shall be a min 2 in. to a max 6-3/4 in. from the other through-penetrants (Item Nos. 2, 3 and 4).

6. **Firestop System** — The firestop system shall consist of the following:

A. **Forms** — (Not Shown) — Used as a form to prevent leakage of fill material during installation. Forms to be a rigid sheet material, cut to fit the contour of the penetrating item and friction fitted into the opening. Forms to be recessed from top surface of floor or both surfaces of wall as required to accommodate the required thickness of fill material. Forms to be removed after fill material has cured.

B. Fill, Void or Cavity Material* — Mortar — Min 3 in. thickness of fill material installed flush with top surface of floor and both surfaces of wall. If **Pre-Cast Concrete Units*** (Item 1) are used, hollow core within the units are to be back filled with a min 4 in. thickness of fill material. Fill material to be mixed at a rate of 2.7 parts dry mixture to one part water by weight in accordance with the installation instructions supplied with the product.

A/D FIRE PROTECTION SYSTEMS INC — A/D FireBarrier Mortar.

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 1997-12-09

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".