



XHEZC.SP326 Firestop Systems

[Page Bottom](#)

Firestop Systems

[See General Information for Firestop Systems](#)


System No. SP326

October 03, 2005

(For Vertical Separation)

F and FH Ratings - 2 h

FT and FTH Ratings - 0, 1 and 1-1/2 h (See Item 2)



1. **Wall Assembly** — The fire-rated gypsum wallboard and stud assembly shall be constructed of the materials and in the manner described in the individual wall or partition design in the ULC List of Equipment and Materials, Fire Resistance, and shall include the following construction features:

(a) **Studs** — Wall framing may consist of either wood studs or steel channel studs. Wood studs to consist of nominal 38 mm by 89 mm lumber spaced 406 mm OC. Steel studs to be minimum 63 mm wide and spaced maximum 610 mm OC. In steel stud walls, additional studs shall be installed horizontally and attached to the vertical studs by means of 13 mm long self-drilling, self-tapping steel screws. The horizontal studs should be positioned in such a manner that a maximum size opening of 600 mm wide by 300 mm high is formed. In wood stud walls, additional studs shall be installed horizontally to vertical studs to create a framed opening such that the maximum size of opening is 368 mm wide by 300 mm high.

(b) **Gypsum Wallboard** — Minimum 12.7 mm thick gypsum wallboard installed vertically in two layers on both sides of stud framing with joints of each layer centred over studs. Inner layer joints on opposite sides of wall staggered one stud. Outer layer joints staggered one stud from inner layer joints.

2. Pipes, Cables and Cable Tray — All penetrating items to be reliably supported.

(a) Maximum size 90 mm by 450 mm steel ladder cable tray spaced minimum 25 mm from perimeter of opening. Maximum cable and conduit loading not to exceed 50% by area of cable tray and made up of the following groupings:

(i) A maximum of 10 (ten) 500 MCM COREFLEX II RA90 (XLPE) FT4 cable (or smaller).

(ii) Individual or bundles of a maximum of 7 (seven) 24 AWG 100 pair telephone CSA Type IWC cables, maximum OD of 18 mm; 13 mm minimum space between bundles or other penetrating items.

(iii) Individual or bundles of a maximum of 7 (seven) CAROL C1160 RG 11/U coaxial cables, maximum 10.3 mm OD; 13 mm minimum space between bundles or other penetrating items.

(iv) A maximum of one 55 mm OD, 1.75 mm minimum wall thickness steel conduit.

(b) A maximum of one nominal 55 mm OD (or smaller) steel conduit with minimum 1.75 mm wall thickness centred in an opening within the mortar compound (Item 3). Size of opening to be such that an annular space around penetrating item is maximum 6.4 mm wide. Opening to be minimum 50 mm from edge of gypsum wallboard opening and other penetrating items.

(c) Nominal 105 mm OD (maximum) copper, steel, cast or ductile iron pipe, or 105 mm OD steel conduit, with minimum 2.39 mm wall thickness spaced 25 mm from the edge of opening and 50 mm minimum from other penetrating items.

Type of Penetrating Item	FT and FTH Ratings, h
Coaxial cable, Item 2a (iii)	1-1/2
Steel conduit, Item 2a (iv)	1
Other penetrating items	0

■ **3. Firestop System Components** — (XHJZC).

(a) Type "A/D FIREBARRIER Mortar" compound prepared by mixing mortar powder with water at a ratio of 1 bag (7 kg) of powder to 2.5 kg of water in accordance with the manufacturer's instructions. The mortar compound is trowelled into the opening to a minimum thickness of 114 mm flush with wall surface.

(b) Type "A/D FIREBARRIER Mineral Wool" to be compressed 33% (minimum) between pipe (Item 2b) and edge of opening. Minimum depth of 100 mm. Minimum 6.4 mm deep space to be left above mineral wool for sealant (Item 3c).

(c) Type "A/D FIREBARRIER Silicone Sealant" applied over mineral wool (Item 3b) to a minimum depth of 6.4 mm on both sides of the assembly at pipe (Item 2b) repenetration.

A/D FIRE PROTECTION SYSTEMS INC

Last Updated on 2005-10-03

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

Copyright © 2016 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2016 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

