



**System No. C-AJ-5305**  
**XHEZ7.C-AJ-5305**  
**Through-penetration Firestop Systems Certified for Canada**

[Page Bottom](#)

**Design/System/Construction/Assembly Usage Disclaimer**

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

**XHEZ - Through-penetration Firestop Systems**

**XHEZ7 - Through-penetration Firestop Systems Certified for Canada**


[See General Information for Through-penetration Firestop Systems](#)

[See General Information for Through-penetration Firestop Systems Certified for Canada](#)

**System No. C-AJ-5305**

April 22, 2016

| <b>ANSI/UL1479 (ASTM E814)</b>                 | <b>CAN/ULC S115</b>                              |
|--|--|
| F Rating — 2 and 3 Hr (See Item 4B)            | F Rating — 2 and 3 Hr (See Item 4B)              |
| T Rating — 1, 1-1/4 and 1-1/2 Hr (See Item 4B) | FT Rating — 1, 1-1/4 and 1-1/2 Hr (See Item 4B)  |
|  | FH Rating — 2 and 3 Hr (See Item 4B)             |
|  | FTH Rating — 1, 1-1/4 and 1-1/2 Hr (See Item 4B) |



## FIRESTOP CONFIGURATION A

1. **Floor or Wall Assembly** — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf (1600-2400 kg/m<sup>3</sup>)) concrete floor or min 5 in. (127 mm) thick reinforced lightweight or normal weight concrete wall. Wall may also be constructed of any UL Classified **Concrete Blocks\***. Floor may also be constructed of any min 6 in. (152 mm) thick UL Classified hollow-core **Precast Concrete Units\***. If the firestop system is installed within a hollow-core precast concrete unit, max diam of opening shall be 7 in. (178 mm) Otherwise, see Table under Item 4B for max diam of opening.

See **Concrete Blocks** (CAZT) and **Precast Concrete Units** (CFTV) categories in the Fire Resistance Directory for names of manufacturers.

2. **Through Penetrants** — One metallic pipe or tubing to be installed either concentrically or eccentrically within the firestop system. Pipe or tubing to be rigidly supported on both sides of floor or wall assembly. See Table under Item 4B for max sizes of pipes that may be used. The following types of metallic pipes or tubing may be used:

- A. **Steel Pipe** — Schedule 10 (or heavier) steel pipe.
- B. **Iron Pipe** — Cast or ductile iron pipe.
- C. **Copper Tubing** — Type L (or heavier) copper tubing.
- D. **Copper Pipe** — Regular (or heavier) copper pipe.

3. **Pipe Covering\*** — Nom 1, 2 or 3 in. (25, 51 or 76 mm) thick (see table under Item 4B) hollow cylindrical heavy density (min 3.5 pcf (56 kg/m<sup>3</sup>)) glass fiber units jacketed on the outside with an all service jacket. Longitudinal joints sealed with metal fasteners or factory-applied self-sealing lap tape. Transverse joints secured with metal fasteners or with butt tape supplied with the product. See Table under Item 4B for annular space required within the firestop system.

See **Pipe and Equipment Covering Materials** (BRGU) category in the Building Materials Directory for names of manufacturers. Any pipe covering material meeting the above specifications and bearing the UL Classification Marking with a Flame Spread Index of 25 or less and a Smoke Developed Index of 50 or less may be used.

4. **Firestop System** — The firestop system shall consist of the following:

A. **Packing Material** — Min 4 pcf (64 kg/m<sup>3</sup>) mineral wool batt insulation firmly packed into opening, to the min thickness specified in the table under Item 4B, as a permanent form. Packing material to be recessed from top surface of floor or from both surfaces of wall and hollow-core precast concrete unit as required to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material\* — Caulk** — Fill material applied within the annulus, flush with top surface of floor or with both surfaces of wall and hollow-core precast concrete unit. Min thickness of fill material specified in table below.

**A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Intumescent Sealant, A/D FIREBARRIER Intumescent Sealant II**

| F<br>Rating<br>Hr | T<br>Rating<br>Hr | Max<br>Pipe<br>Diam,<br>in. (mm) |                | Pipe<br>Covering<br>Thick,<br>in. (mm) | Packing<br>Material<br>Thick,<br>in.<br>(mm) | Max<br>Open<br>Diam,<br>in.<br>(mm) | Fill<br>Mtl<br>Thick<br>in.<br>(mm) | Annular<br>Space,<br>in.<br>(mm) |
|-------------------|-------------------|----------------------------------|----------------|--|--|-------------------------------------|-------------------------------------|----------------------------------|
|                   |                   | Copper                           | Steel,<br>Iron |  |  |                                     |                                     |                                  |
| 2                 | 1                 | 4 (102)                          | 6 (152)        | 1 (25)                                 | 4 (102)                                      | 8-5/8 (219)                         | 1/2 (13)                            | 1/2 to 1-3/8 (13 to 35)          |
| 3                 | 1-1/2             | 4 (102)                          | 6 (152)        | 2 (51)                                 | 3-1/2 (89)                                   | 10-5/8 (270)                        | 1 (25)                              | 1/2 to 1-3/8 (13 to 35)          |
| 2                 | 1-1/2             | 6 (152)                          | 8 (152)        | 3 (76)                                 | 3-1/2 (89)                                   | 18-3/4 (476)                        | 1 (25)                              | 1-3/4 to 2 (44 to 51)            |

**\* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2016-04-22

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".