



System No. C-AJ-1557
XHEZ.C-AJ-1557
Through-penetration Firestop Systems

[Page Bottom](#)

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

XHEZ - Through-penetration Firestop Systems

XHEZ7 - Through-penetration Firestop Systems Certified for Canada


[See General Information for Through-penetration Firestop Systems](#)

[See General Information for Through-penetration Firestop Systems Certified for Canada](#)


System No. C-AJ-1557

April 08, 2016


ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Ratings — 2 and 3 Hr (See Item 3)	F Ratings — 2 and 3 Hr (See Item 3)
T Rating — 0 Hr	FT Rating — 0 Hr
	FH Ratings — 2 and 3 Hr (See Item 3)
	FTH Rating — 0 Hr




CONFIGURATION A



CON FIGURATION B



CON FIGURATION C



1. **Floor or Wall Assembly** — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf (1600-2400 kg/m³)) concrete floor or min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight concrete wall. The min thickness of the wall is dependent upon the firestop configuration as shown in Item 3. Wall may also be constructed of any UL Classified **Concrete Blocks***. Floor may also be constructed of any min 6 in. (152 mm) thick UL Classified hollow-core **Precast Concrete Units***. If the firestop system is installed within a hollow-core precast concrete unit, max diam of opening shall be 7 in. (203 mm). Otherwise, max diam of opening is 15 1/4 in. (391 mm).

See **Concrete Blocks** (CAZT) and **Precast Concrete Units** (CFTV) categories in the Fire Resistance Directory for names of manufacturers.

1A. **Metallic Sleeve** — (Optional) — Nom 14 in. (356 mm) diam (or smaller) Schedule 10 (or heavier) steel sleeve cast or grouted into floor or wall assembly, flush with floor or wall surfaces. As an option, sleeve may extend max 2 in. (51 mm) above top surface of floor or beyond one or both surfaces of wall. The use of the steel sleeve is dependent upon the firestop configuration as shown in Item 3.

2. **Through Penetrants** — One metallic pipe, conduit or tubing to be installed either concentrically or eccentrically within the firestop system. The annular space the between pipe, conduit or tubing and periphery of opening is dependent upon the type and max diam of through penetrant and the firestop configuration as shown in Item 3. Pipe, conduit or tubing to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of metallic pipes, conduits or tubing may be used:

A. **Steel Pipe** — Nom 12 in. (305 mm) diam (or smaller) Schedule 10 (or heavier) steel pipe.

B. **Iron Pipe** — Nom 12 in. (305 mm) diam (or smaller) cast or ductile iron pipe.

C. **Conduit** — Nom 4 in. (102 mm) diam (or smaller) steel electrical metallic tubing or nom 6 in. (152 mm) diam (or smaller) steel conduit.

D. **Copper Tubing** — Nom 6 in. (152 mm) diam (or smaller) Type L (or heavier) copper tubing.

E. **Copper Pipe** — Nom 6 in. (152 mm) diam (or smaller) Regular (or heavier) copper pipe.

3. **Firestop System** — The F Rating of the firestop system is dependent upon the min thickness of the wall, type and max nom diam of the through penetrant, min and max annular space within the firestop system and the firestop configuration as shown in the table below:

Min Thickness of Wall, In. (mm)	Type of Through Penetrant	Max Nom Diam of Through Penetrant, In. (mm)	Use of Steel Sleeve	Min, Max Annular, In. (mm)	Firestop Configuration	F Rating, Hr
4-3/4 (121)	Steel Pipe & Iron Pipe	12 (305)	Optional	0, 2 (0, 51)	A	3
4-3/4 (121)	Steel Conduit, Copper Tube & Copper Pipe	6 (152)	Optional	0, 2 (0, 51)	A	3
4-3/4 (121)	Steel EMT	4 (102)	Optional	0, 2 (0, 51)	A	3

4-1/2 (114)	Steel Pipe & Iron Pipe	12	Not Applicable	0, 2 (0, 51)	B	2
4-1/2 (114)	Steel Conduit, Copper Tube & Copper Pipe	6 (152)	Not Applicable	0, 2 (0, 51)	B	2
4-1/2 (114)	Steel EMT	4 (102)	Not Applicable	0, 2 (0, 51)	B	2
5-1/4 (131)	Steel Pipe & Iron Pipe	8 (203)	Optional	0, 2 (0, 51)	C	3
5-1/4 (131)	Steel Conduit, Copper Tube, Copper Pipe & Steel EMT	4 (102)	Optional	0, 2(0, 51)	C	3
4-1/2 (114)	Steel Pipe & Iron Pipe	8 (203)	Not Applicable	0, 7/8 (0, 22)	D	2
4-1/2 (114)	Steel Conduit , Copper Tube, Copper Pipe & Steel EMT	4 (102)	Not Applicable	0, 7/8 (0, 22)	D	2

The firestop system shall consist of the following:

Configuration A

A. **Packing Material** — Min 4-1/4 in (108 mm) thickness of 4 pcf (64 kg/m³) mineral wool batt insulation firmly packed into opening as a permanent. Packing material to be recessed from top surface of floor or top end of sleeve or from both surfaces of wall and hollow-core precast concrete units or ends of sleeve as required to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material* — Caulk** — Min 1/4 in. (6 mm) of fill material applied within the annulus, flush with top surface of floor or top end of sleeve, or with both surfaces of wall and hollow-core precast concrete units or ends of sleeve.

A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Intumescent Sealant, A/D FIREBARRIER Intumescent Sealant II

Configuration B

A. **Packing Material** — Foam backer rod firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor or both surfaces of wall and hollow-core precast concrete units as required to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material* — Caulk** — Min 1 in. (25 mm) thickness of fill material applied within the annulus, flush with top surface of floor or with both surfaces of wall and hollow-core precast concrete units. A min 1/4 in. (6 mm) bead of fill material shall be applied at point contact location on top surface of floor and both surfaces of wall or hollow-core precast concrete units.

A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Intumescent Sealant, A/D FIREBARRIER Intumescent Sealant II

Configuration C

A. **Packing Material** — Min 3-3/4 in. (95 mm) thickness of 4 pcf (64 kg/m³) mineral wool batt insulation firmly packed into opening as a permanent form. Packing material shall be recessed 3/4 in. from bottom of floor or both surfaces of wall or ends of sleeve to accommodate the required thickness of fill material.

B. Fill, Void or Cavity Material* — Caulk — Min 3/4 in. (19 mm) thickness of fill material applied within the annulus, flush with bottom surface of floor or with both surfaces of wall or ends of sleeve.

A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Intumescent Sealant, A/D FIREBARRIER Intumescent Sealant II

Configuration D

A. Packing Material — Foam backer rod firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor or both surfaces of wall and hollow-core precast concrete units as required to accommodate the required thickness of fill material.

B. Fill, Void or Cavity Material* — Caulk — Min 1/2 in. (13 mm) thickness of fill material applied within the annulus, flush with top surface of floor or with both surfaces of wall and hollow-core precast concrete units. A min 1/4 in. (6 mm) bead of fill material shall be applied at point contact location on top surface of floor and both surfaces of wall or hollow-core precast concrete units.

A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Intumescent Sealant, A/D FIREBARRIER Intumescent Sealant II

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2016-04-08

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".