



**System No. C-AJ-1229**  
**XHEZ7.C-AJ-1229**  
**Through-penetration Firestop Systems Certified for Canada**

[Page Bottom](#)

---

**Design/System/Construction/Assembly Usage Disclaimer**

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
  - Authorities Having Jurisdiction should be consulted before construction.
  - Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
  - When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
  - Only products which bear UL's Mark are considered Certified.
- 

**XHEZ7 - Through-penetration Firestop Systems Certified for Canada**

[See General Information for Through-penetration Firestop Systems Certified for Canada](#)

**System No. C-AJ-1229**


September 12, 2011

**F Rating — 2 Hr**

**FT Rating — 0 Hr**


**FH Rating — 2 Hr**

**FTH Rating — 0 Hr**



SECTION A-A

FIRESTOP CONFIGURATION A



SECTION A-A

FIRESTOP CONFIGURATION B

1. **Floor or Wall Assembly** — Min 4-1/2 in. thick reinforced normal weight (140-150 pcf) concrete. Floor may also be constructed of any min 6 in. thick UL Classified hollow-core **Precast Concrete Units\***. Wall may also be constructed of any UL Classified **Concrete Blocks\***. Max diam of opening is 12-1/2 in. If the firestop system is installed within a hollow-core precast concrete unit, max dimension of opening shall be 7 in.

See **Concrete Blocks** (CAZT) and **Precast Concrete Units** (CFTV) categories in the Fire Resistance Directory for names of manufacturers.

2. **Through Penetrant** — One metallic pipe or conduit to be installed either concentrically or eccentrically within the firestop system. The annular space between pipes or conduits and periphery of opening shall be min 0 in. to max 3-7/8 in. Pipe or conduit to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of metallic pipes or conduits may be used:

A. **Steel Pipe** — Nom 8 in. diam (or smaller) Schedule 40 (or heavier) steel pipe.

B. **Iron Pipe** — Nom 8 in. diam (or smaller) cast or ductile iron pipe.

C. **Conduit** — Nom 4 in. diam (or smaller) steel electrical metallic tubing or nom 6 in. diam steel conduit.

3. **Firestop System** — The firestop system shall consist of the following:

#### **Firestop Configuration A**

A. **Packing Material** — Min 4 in. thickness of min 4 pcf mineral wool batt insulation firmly packed into opening as a permanent form. Packing material to be recessed from bottom surface of floor or from both surfaces of wall as required to accommodate the required thickness of fill material. When the floor is constructed of hollow-core precast concrete units, packing material shall be recessed from bottom surface of floor to accommodate the required thickness of fill material and installed flush with top surface of floor.

B. **Fill, Void or Cavity Material\* — Sealant** — Min 1/4 in. thickness of fill material applied within the annulus, flush with the bottom surface of floor or on both surfaces of wall assembly. At the point contact location between through penetrant and concrete, a min 1/4 in. diam bead of fill material shall be applied at the concrete/through penetrant interface on the bottom surface of floor and on both surfaces of wall.

**A/D FIRE PROTECTION SYSTEMS INC** — A/D FIREBARRIER SILICONE (floors, pre-cast concrete units and walls)

#### **Firestop Configuration B**

A. **Packing Material** — Min 4 in. thickness of min 4 pcf mineral wool batt insulation firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor or from both surfaces of wall as required to accommodate the required thickness of fill material. When the floor is constructed of hollow-core precast concrete units, packing material shall be recessed from both surfaces of floor to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material\* — Sealant** Min 1/4 in. thickness of fill material applied within the annulus, flush with the top surface of floor or on both surfaces of wall assembly. When the floor is constructed of hollow-core precast concrete units, fill material shall be installed flush with both surfaces of floor. At the point contact location between through penetrant and concrete, a min 1/4 in. diam bead of caulk grade fill material shall be applied at the concrete/through penetrant interface on the top surface of floor and on both surfaces of wall and hollow-core precast concrete units.

**A/D FIRE PROTECTION SYSTEMS INC** — A/D FIREBARRIER SILICONE SL (floors only) and A/D FIREBARRIER SILICONE (floors, pre-cast concrete units and walls)

\*Bearing the UL Classification Marking

Last Updated on 2011-09-12

---

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".