



## XHEZC.SP927 Firestop Systems

[Page Bottom](#)

### Firestop Systems

[See General Information for Firestop Systems](#)


### System No. SP927

October 04, 2005

(For Vertical Separation)

F and FH Ratings — 2 h

FT and FTH Ratings — 0 h



1. **Wall Assembly** — The 2 h fire-rated gypsum wallboard/stud wall assembly shall be constructed of the materials and in the manner specified in the individual Wall or Partition designs in the Underwriters' Laboratories of Canada List of Equipment and Materials and shall include the following construction features:

(a) **Studs** — Wall framing may consist of either wood studs or steel channel studs. Wood studs to consist of nom 50 mm by 102 mm lumber spaced 405 mm OC. Steel studs to be min 92 mm wide and spaced max 600 mm OC.

(b) **Wallboard, Gypsum** — Two layers, nom 16 mm thick, 1220 mm wide with square or tapered edges. The gypsum wallboard type, fastener type and sheet orientation shall be as specified in the individual wall or partition design. Diam of opening in wallboard layers to be 47.5 mm larger than outside diam of pipe for both the 50 mm diam and 75 mm diam pipe. Max diam

of opening in wallboard layers is 102 mm for 50 mm diam pipe and 127 mm for 75 mm diam pipe.

2. **Metal Pipe** — Nom 76 mm diam (or smaller) Schedule 10 (or heavier) steel pipe, cast or ductile iron pipe Type L (or heavier) copper pipe or steel electrical metallic tubing or steel conduit. One pipe to be installed either concentrically or eccentrically with the firestop system. The annular space between the pipe and the edge of the through-opening shall be min 0 mm (point contact) to max 47.5 mm. Pipe to be rigidly supported on both sides of wall assembly.

■ 3. **Firestop System Components** — (XHJZC). Type "A/D FIREBARRIER Silicone" installed to fill the annular space throughout thickness of gypsum wallboard layers flush with each surface of the wall. A min 6.4 mm diam bead of silicone shall be applied to the pipe/wallboard interface at the point contact location on both sides of the wall.

#### **A/D FIRE PROTECTION SYSTEMS INC**

Last Updated on 2005-10-04

---

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

Copyright © 2016 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2016 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

