



XHEZC.SP988 Firestop Systems

[Page Bottom](#)

Firestop Systems


[See General Information for Firestop Systems](#)

System No. SP988

October 05, 2005

F Rating — 2 h

FT, FH and FTH Ratings — 0 h



1. **Wall Assembly** — Minimum 156 mm thick lightweight or normal-density concrete. Wall may be constructed of any nominal 200 mm thick concrete block. Maximum size of opening is 1016 mm by 508 mm.

2. **Duct** — Maximum 457 mm by 965 mm galvanized steel duct, 0.71 mm in thickness. Maximum separation of 51 mm between duct and periphery of opening. Duct to be rigidly supported on both sides of the wall.

3. **Steel Angle** —

(a) Nominal 75 mm by 50 mm by 1.5 mm steel angle installed on the two faces of the duct separated from wall using sheet metal screws between the 50 mm leg of the angle and the duct, installed a maximum of 110 mm OC.

(b) Nominal 50 mm by 25 mm by 1.5 mm steel angle installed on the two faces of the duct in contact with the wall, using sheet metal screws between the 50 mm leg of the angle and the

duct, installed a maximum of 110 mm OC.

- **4. Firestop System Components** — (XHJZC) - Type "A/D FIREBARRIER Silicone Sealant" installed with 6.4 mm bead on each leg of steel angle and compressed between angle and duct and angle and wall. Additional 6.4 mm bead of sealant installed as crown bead between duct and wall at point of contact.

A/D FIRE PROTECTION SYSTEMS INC

Last Updated on 2005-10-05

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

Copyright © 2016 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2016 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

