



System No. F-E-1015 XHEZ7.F-E-1015 Through-penetration Firestop Systems Certified for Canada

[Page Bottom](#)

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

XHEZ7 - Through-penetration Firestop Systems Certified for Canada

[See General Information for Through-penetration Firestop Systems Certified for Canada](#)

System No. F-E-1015


September 22, 2011

F Rating — 1 Hr

FT Rating — 1 Hr

FH Rating — 1 Hr

FTH Rating — 1 Hr



1. Floor-Ceiling Assembly — The 1 hr fire rated concrete and steel joist Floor-Ceiling assembly shall be constructed of the materials and in the manner described in the individual G500 Series Design in the UL Fire Resistance Directory, as summarized below:

A. Flooring — Normal or Lightweight concrete as specified in the individual G500 Series Design.
Max diam of opening is 7 in.

B. **Joists** — Steel joists or Structural Steel Members* as specified in the individual G500 Series Design.

C. **Gypsum Board*** — Min 5/8 in. thick, screw-attached to furring channels as specified in the individual G500 Series Design. Max diam of opening is 7 in.

2. **Through Penetrant** — One metallic pipe, conduit or tubing to be installed centered within the opening, approx midway between joists. The annular space between penetrant and periphery of opening shall be a nom 1/4 in. Penetrants to be rigidly supported on both sides of floor assembly. The following types and sizes of metallic pipes, conduits or tubing may be used:

A. **Steel Pipe** — Nom 6 in. diam (or smaller) Schedule 10 (or heavier) steel pipe.

B. **Iron Pipe** — Nom 6 in. diam (or smaller) cast or ductile iron pipe.

C. **Conduit** — Nom 6 in. diam (or smaller) steel conduit, or nom 4 in. (or smaller) electrical metallic tubing.

D. **Copper Tubing** — Nom 4 in. diam (or smaller) Type L (or heavier) copper tube.

E. **Copper Pipe** — Nom 4 in. diam (or smaller) Regular (or heavier) copper pipe.

3. **Fill, Void or Cavity Materials* — Caulk** — Min 1-1/8 in. thickness of fill material applied within the annulus, flush with top surface of floor. Min 5/8 in. thickness of fill material applied within the annulus, flush with bottom surface of ceiling. Additional fill material shall be installed such that a min 1/2 in. thick crown of fill material applied around the through penetrant on both the top and bottom surfaces of the assembly.

A/D FIRE PROTECTION SYSTEMS INC — A/D FIREBARRIER Silicone

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2011-09-22

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".