

MERIDIAN ELEVATOR SERVICES

Annual Safety Inspection Certificate

Certificate No: MES-2026-4103
Unit ID: E85-4
Building: Northgate Exchange
Address: 760 Northgate Blvd, Reno, NV 89501
Unit Type: Traction Passenger
Capacity (lbs): 2100
Inspection Date: 07/02/2026
Next Due: 07/02/2027
Inspector: K. Nakamura
Result: PASS WITH DEFECTS
Invoice Total: \$878.05

Defects Noted:

- Door restrictor worn beyond tolerance
- Firefighter recall Phase II delayed
- Emergency lighting battery below spec