

Meridian Elevator Services, Inc.

Conveyance Inspection Record - retain for jurisdiction audit

CERT MES-2026-4113	Unit: B95-6
Alder Commons	Freight
4501 Alder Loop	2100 lb
Boise, ID 83702	

Date of Inspection	06/09/2026
Re-inspection Due	06/09/2027
Certified By	T. Moreau
Disposition	FAIL
Amount Billed	\$285.82

DEFICIENCIES

1. Governor tripping speed out of range
2. Door restrictor worn beyond tolerance