

Meridian Elevator Services, Inc.

Conveyance Inspection Record - retain for jurisdiction audit

CERT MES-2026-4116	Unit: B80-4
Harborview Tower	Traction Passenger
1100 Beacon St	3000 lb
Portland, OR 97205	

Date of Inspection	02/04/2026
Re-inspection Due	02/04/2027
Certified By	A. Vasquez
Disposition	FAIL
Amount Billed	\$1,626.78

DEFICIENCIES

1. Car top guard rail height noncompliant
2. Governor tripping speed out of range