

Meridian Elevator Services, Inc.

Conveyance Inspection Record - retain for jurisdiction audit

CERT MES-2026-4119	Unit: C10-3
Kestrel Plaza	Traction Passenger
88 Ninth Ave	2100 lb
Denver, CO 80202	

Date of Inspection	07/20/2026
--------------------	------------

Re-inspection Due	07/20/2027
-------------------	------------

Certified By	A. Vasquez
--------------	------------

Disposition	PASS WITH DEFECTS
-------------	-------------------

Amount Billed	\$1,389.77
---------------	------------

DEFICIENCIES

1. Hoistway lighting inoperative
2. Firefighter recall Phase II delayed