

Meridian Elevator Services, Inc.

Conveyance Inspection Record - retain for jurisdiction audit

CERT MES-2026-4128	Unit: B47-5
Copperfield Center	Traction Passenger
9 Copperfield Way	2500 lb
Bend, OR 97701	

Date of Inspection	01/10/2026
--------------------	------------

Re-inspection Due	01/10/2027
-------------------	------------

Certified By	R. Okonkwo
--------------	------------

Disposition	FAIL
-------------	------

Amount Billed	\$1,845.90
---------------	------------

DEFICIENCIES

1. Door restrictor worn beyond tolerance
2. Hoistway lighting inoperative