



## AI DIGITAL TWIN REPORT

### Gasonet CNG Station

Report ID : RPT-20260628-154142

Generated : 28 June 2026 15:41:42

### Station Information

| Station Name | Gasonet CNG Station           |
|--------------|-------------------------------|
| Location     | Sundernagar, Himachal Pradesh |
| Station Type | Daughter Booster Station      |
| Gas Source   | Mobile Cascade                |

### Compressor Information

| Equipment     | Booster Compressor |
|---------------|--------------------|
| Compressor ID | BC-01              |
| Manufacturer  | Ariel Corporation  |
| Capacity      | 500 SCM/hr         |

### Operating Parameters

| Parameter          | Value        |
|--------------------|--------------|
| Suction Pressure   | 82.0 Bar     |
| Discharge Pressure | 121.0 Bar    |
| Voltage            | 418.0 V      |
| Current            | 18.0 A       |
| Flow Rate          | 333.0 SCM/hr |
| Running Hours      | 2.0 hr       |
| Actual KWH         | 36.0         |

### AI Prediction Summary

|               |       |
|---------------|-------|
| Predicted KWH | 36.87 |
|---------------|-------|

|                   |           |
|-------------------|-----------|
| Compressor Health | 97.68%    |
| System Status     | Excellent |

Alarm Summary

| Severity | Message         |
|----------|-----------------|
| NORMAL   | No Active Alarm |

Maintenance Recommendation

Inspect motor current, bearings and electrical loading.

Generated Automatically by AI Smart CNG Station Management System

Gasonet Digital Twin Version 2.0