

FORMULIR MONITORING PENERANGAN

Tanggal :
Waktu :
Pemeriksa :

NO	AREA	TITIK PENILAIAN			STANDAR	KETERANGAN
		1	2	3		
1	Ruangan PJO				300 lux	
2	Ruangan HSE				300 lux	
3	Ruangan Meeting				300 lux	
4	Ruangan Pengawas				300 lux	
5	Logistik				100 lux	
6	Ruangan MCC				200 lux	
7	Ruangan CCR				300 lux	
8	Tangga CCR				100 lux	
9	Ruangan Genset				200 lux	
10	Ruangan LVMDP				200 lux	
11	Ruangan Trafo				200 lux	
12	Hopper A				100 lux	
13	Hopper B				100 lux	
14	Feeder Breaker				100 lux	
15	Tail CV 01 A				100 lux	
16	Walkway CV 01 A (L)				100 lux	
17	Walkway CV 01 A (R)				100 lux	
18	Lantai 4 TT 01 A				100 lux	
19	Roller Screen				100 lux	
20	Crusher Line A				200 lux	
21	Lantai 1 TT 01 A				100 lux	
22	Walkway CV 02 A (L)				100 lux	
23	Walkway CV 02 A (R)				100 lux	
24	Lantai 3 TT 02 A				100 lux	
25	Tail CV 03 A				100 lux	
26	Walkway CV 03 A (L)				100 lux	
27	Walkway CV 03 A (R)				100 lux	

NO	AREA	TITIK PENILAIAN			STANDAR	KETERANGAN
		1	2	3		
28	Screw				100 lux	
29	Tail CV 01 B				100 lux	
30	Walkway CV 01 B (L)				100 lux	
31	Walkway CV 01 B (R)				100 lux	
32	Lantai 4 TT 01 B				100 lux	
33	Lantai 3 TT 01 B				100 lux	
34	Crusher Line B				200 lux	
35	Lantai 1 TT 01 B				100 lux	
36	Walkway CV 02 B (L)				100 lux	
37	Walkway CV 02 B (R)				100 lux	
38	Lantai 3 TT 02 B				100 lux	
39	Tail CV 03 B				100 lux	
40	Walkway CV 03 B (L)				100 lux	
41	Walkway CV 03 B (R)				100 lux	
42	Jalan CPP				20 lux	
43	Belokan MCC				20 lux	

Diperiksa Oleh

Diketahui Oleh

Prananda Abriasnyah
Safety Patrol

M. Daffa Djatmiko Aji
PJO