

	Energy Yield Assessment Report Los Olmos (CL) 23 x N149/4.0-4.5 (Mode 0.a) TS145-01 IEC S	E0004801367 Revision 06 2020-07-08
---	--	--

A1.4 Energy yields

AEP per turbine (20 years, all yields in [MWh/a])

No	GROSS AEP [MWh/a]	Effi- ciency [%]	PARK AEP [MWh/a]	losses [MWh/a]	losses [%]	NET AEP P50	Full- load hours	CoV 20y [%]	P75	P90
T01-AE01	20311	96.2%	19548	-1529	7.5%	18020	4004	12.9%	16450	15037
T02-AE02	20705	91.0%	18841	-1558	7.5%	17283	3841	12.3%	15845	14551
T03-AE04	19866	92.4%	18356	-1495	7.5%	16861	3747	12.7%	15413	14110
T04-AE05	19771	90.2%	17839	-1488	7.5%	16351	3633	12.9%	14923	13638
T05-AE06	19767	90.2%	17835	-1488	7.5%	16347	3633	12.6%	14957	13707
T07-AE08	20022	84.8%	16985	-1507	7.5%	15478	3440	12.2%	14205	13058
T08-AE09	20263	90.2%	18284	-1525	7.5%	16759	3724	11.7%	15437	14246
T09-AE10	20670	89.2%	18447	-1556	7.5%	16891	3754	11.2%	15615	14467
T10-AE11	21118	94.4%	19935	-1589	7.5%	18346	4077	10.7%	17019	15825
T11-AE12	20478	95.0%	19445	-1541	7.5%	17904	3979	11.0%	16576	15381
T12-AE13	20616	97.9%	20187	-1552	7.5%	18635	4141	11.2%	17222	15950
T13-AE16	19829	85.4%	16926	-1492	7.5%	15433	3430	11.3%	14258	13201
T14-AE17	20435	87.9%	17954	-1538	7.5%	16416	3648	10.8%	15221	14145
T15-AE18	20488	96.5%	19778	-1542	7.5%	18236	4053	10.4%	16958	15807
T16-AE19	20716	94.5%	19568	-1559	7.5%	18009	4002	10.2%	16775	15665
T17-AE20	20147	93.9%	18919	-1516	7.5%	17403	3867	10.4%	16179	15077
T18-AE21	19526	85.7%	16739	-1470	7.5%	15270	3393	11.2%	14121	13087
T19-AE22	20140	93.3%	18789	-1516	7.5%	17273	3839	10.3%	16076	14998
T20-AE23	20128	95.7%	19270	-1515	7.5%	17755	3946	10.2%	16532	15432
T21-AE24	20291	97.4%	19760	-1527	7.5%	18232	4052	10.1%	16986	15864
T22-AE03	20611	86.3%	17778	-1551	7.5%	16226	3606	12.4%	14873	13654
T23-AE15	20202	86.4%	17463	-1520	7.5%	15943	3543	11.0%	14759	13694
AG11	19477	97.4%	18969	-1466	7.5%	17503	3890	13.4%	15925	14505