

	Energy Yield Assessment Report Mesamavida (CL) 14 x N149/4.0-4.5 (Mode 0.a) TS145-01 IEC S	E0004857897 Revision 06 2020-03-31
---	---	--

A1.4 Energy yields

AEP per turbine (20 years, all yields in [MWh/a])

No	GROSS AEP [MWh/a]	Effi- ciency [%]	PARK AEP [MWh/a]	losses [MWh/a]	losses [%]	NET AEP P50	Full- load hours	CoV 20y [%]	P75	P90
T01-AE01	18562	93.3%	17318	-1130	6.1%	16188	3597	9.1%	15195	14302
T02-AE02	18453	93.9%	17332	-1188	6.4%	16144	3588	9.1%	15153	14261
T03-AE03	18404	93.5%	17213	-1103	6.0%	16110	3580	9.1%	15121	14232
T04-AE05	18086	90.7%	16405	-1107	6.1%	15298	3399	8.3%	14441	13670
T05-AE06	18154	92.6%	16812	-1109	6.1%	15703	3489	8.5%	14802	13990
T06-AE07	17901	85.9%	15382	-1094	6.1%	14289	3175	9.5%	13372	12547
T07-AE08	17837	85.9%	15324	-1091	6.1%	14233	3163	9.6%	13312	12483
T08-AE09	18146	89.0%	16142	-1109	6.1%	15033	3341	8.6%	14165	13384
T09-AE10	18163	88.0%	15980	-1112	6.1%	14868	3304	8.7%	13994	13208
T10-AE12	19245	85.1%	16372	-1440	7.5%	14932	3318	7.7%	14156	13458
T11-AE13	17787	95.8%	17032	-1089	6.1%	15943	3543	7.1%	15180	14493
T12-AE14	17313	93.9%	16254	-1060	6.1%	15194	3376	7.2%	14452	13785
T13-AE15	17866	96.2%	17196	-1094	6.1%	16102	3578	6.9%	15349	14672
T14-AE04	18168	91.1%	16556	-1112	6.1%	15444	3432	8.4%	14564	13771