



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29203-ET-PE5002-1-9WK-1	EHT Controller #:	
Trace Part #:		Panel #:	29152-HFP-001
RTD'(s) #:		Circuit #:	
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required	GF	
1.2 EHT Tag Matches Part # and drawings	N/A	no tags present
1.3 EHT is Routed and Installed as per specifications	GF	
1.4 RTD's Receiving Report has been Completed if required	N/A	
1.5 RTD's are installed as per drawing and specification	N/A	
1.6 EHT/RTD's Tags are correctly labelled and installed	N/A	con tags & cable tags needed
1.7 As-built drawings completed and submitted	GF	
1.8 Terminations are complete with correct wire tags	GF	no tags..
1.9 SR/MI Trace Continuity test passed (Record Resistance)	GF	
1.10 EHT/RTD's Released for Insulation	GF	

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	(Passed/Fail):
	SR/MI @ 1000 VDC	(Passed/Fail): Pass
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
Jay Fox	26/09/05	
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.	PROJECT NAME: K1B Well Pad Project	CONTRACT#: CA23007-SCM-AGC-004	LOCATION: Module Yard
----------------------------------	------------------------------------	--------------------------------	-----------------------

TRACE DATA			
Trace #:	29203-ET-PE5002-2	EHT Controller #:	29151-HTP-001
Trace Part #:	15 HTV1-CT	Panel #:	
RTD'(s) #:	RTD 4AL	Circuit #:	020
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required		
1.2 EHT Tag Matches Part # and drawings		
1.3 EHT is Routed and Installed as per specifications	<i>[Signature]</i>	
1.4 RTD's Receiving Report has been Completed if required		
1.5 RTD's are installed as per drawing and specification	<i>[Signature]</i>	
1.6 EHT/RTD's Tags are correctly labelled and installed		
1.7 As-built drawings completed and submitted		
1.8 Terminations are complete with correct wire tags	<i>[Signature]</i>	Missing Tags
1.9 SR/MI Trace Continuity test passed (Record Resistance)	4.2 <i>[Signature]</i>	
1.10 EHT/RTD's Released for Insulation		

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	2956-2 (Passed/Fail): Passed
	SR/MI @ 1000 VDC	3856-2 (Passed/Fail): Passed
	SR/MI @ 2500 VDC	3956-2 (Passed/Fail): Passed

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29203-ET-ST5001-1	EHT Controller #:	29151-HTP-001
Trace Part #:	D/32503472	Panel #:	
RTD'(s) #:	RTD4AL	Circuit #:	012
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required		
1.2 EHT Tag Matches Part # and drawings		
1.3 EHT is Routed and Installed as per specifications		
1.4 RTD's Receiving Report has been Completed if required		
1.5 RTD's are installed as per drawing and specification		
1.6 EHT/RTD's Tags are correctly labelled and installed		
1.7 As-built drawings completed and submitted		
1.8 Terminations are complete with correct wire tags		Missing Tags
1.9 SR/MI Trace Continuity test passed (Record Resistance)	30-2	
1.10 EHT/RTD's Released for Insulation		

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	6906-2 (Passed/Fail): Passed
	SR/MI @ 1000 VDC	(Passed/Fail):
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
Client Representative	Date (yy/mm/dd)	Signature



EHF & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29203-ET-HC5008-1-3	EHT Controller #:	29151-HTP-001
Trace Part #:	10 HTV1-CT	Panel #:	
RTD'(s) #:	NA	Circuit #:	08
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required		
1.2 EHT Tag Matches Part # and drawings		
1.3 EHT is Routed and Installed as per specifications	<i>OK</i>	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	NA	
1.6 EHT/RTD's Tags are correctly labelled and installed		
1.7 As-built drawings completed and submitted		
1.8 Terminations are complete with correct wire tags	<i>OK</i>	Missing Tags
1.9 SR/MI Trace Continuity test passed (Record Resistance)	11-2 <i>OK</i>	
1.10 EHT/RTD's Released for Insulation		

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	11G-2 (Passed/Fail): Passed
	SR/MI @ 1000 VDC	11G-2 (Passed/Fail): Passed
	SR/MI @ 2500 VDC	7.8G-2 (Passed/Fail): Passed.

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29203-ET-HC5008-1	EHT Controller #:	29151-HTP-001
Trace Part #:	10HTV1-CT	Panel #:	
RTD'(s) #:	RTD4AL	Circuit #:	08
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required		
1.2 EHT Tag Matches Part # and drawings		
1.3 EHT is Routed and Installed as per specifications	YES	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	YES NA	
1.6 EHT/RTD's Tags are correctly labelled and installed		
1.7 As-built drawings completed and submitted		
1.8 Terminations are complete with correct wire tags	YES	Missing Tags
1.9 SR/MI Trace Continuity test passed (Record Resistance)	30-Ω YES	
1.10 EHT/RTD's Released for Insulation		

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	8706-Ω (Passed/Fail): Passed
	SR/MI @ 1000 VDC	2.2T-Ω (Passed/Fail): Passed
	SR/MI @ 2500 VDC	2.2T-Ω (Passed/Fail): Passed.

Comments:

added a splice kit

Yanda Representative	Date (yy/mm/dd)	Signature
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29203-ET-HC5008-1-2	EHT Controller #:	29151-HTP-001
Trace Part #:	10 HTV1-CT	Panel #:	
RTD'(s) #:	NA	Circuit #:	08
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required		
1.2 EHT Tag Matches Part # and drawings		
1.3 EHT is Routed and Installed as per specifications	NA	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	NA	
1.6 EHT/RTD's Tags are correctly labelled and installed		
1.7 As-built drawings completed and submitted		
1.8 Terminations are complete with correct wire tags	NA	missing tags
1.9 SR/MI Trace Continuity test passed (Record Resistance)	11.2 NA	
1.10 EHT/RTD's Released for Insulation		

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	585G-2 (Passed/Fail): passed
	SR/MI @ 1000 VDC	715G-2 (Passed/Fail): passed
	SR/MI @ 2500 VDC	800G-2 (Passed/Fail): passed

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29103-ET-ST1403-1-3	EHT Controller #:	
Trace Part #:		Panel #:	
RTD'(s) #:		Circuit #:	
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required	NA	
1.2 EHT Tag Matches Part # and drawings	JF	
1.3 EHT is Routed and Installed as per specifications	JF	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	NA	
1.6 EHT/RTD's Tags are correctly labelled and installed	JF	
1.7 As-built drawings completed and submitted	NA	
1.8 Terminations are complete with correct wire tags	NA	
1.9 SR/MI Trace Continuity test passed (Record Resistance)	JF	
1.10 EHT/RTD's Released for Insulation	NA	

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	20230300 (Passed/Fail):
	SR/MI @ 1000 VDC	2.2 GΩ (Passed/Fail): Pass.
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
	26/09/03.	
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29103-ET-ST1503-1-1	EHT Controller #:	
Trace Part #:		Panel #:	
RTD'(s) #:		Circuit #:	
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required	NA	
1.2 EHT Tag Matches Part # and drawings	JF	
1.3 EHT is Routed and Installed as per specifications	JF	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	NA	
1.6 EHT/RTD's Tags are correctly labelled and installed	JF	
1.7 As-built drawings completed and submitted	NA	
1.8 Terminations are complete with correct wire tags	JF NA	
1.9 SR/MI Trace Continuity test passed (Record Resistance)	JF	
1.10 EHT/RTD's Released for Insulation	NA	

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	(Passed/Fail): Pass Fail
	SR/MI @ 1000 VDC	(Passed/Fail): Pass
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
	26/09/03.	
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29103-ET-ST1303-1-3	EHT Controller #:	
Trace Part #:		Panel #:	
RTD'(s) #:		Circuit #:	
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required	NA	
1.2 EHT Tag Matches Part # and drawings	JF	
1.3 EHT is Routed and Installed as per specifications	JF	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	NA	
1.6 EHT/RTD's Tags are correctly labelled and installed	JA	
1.7 As-built drawings completed and submitted	NA	
1.8 Terminations are complete with correct wire tags	NA	
1.9 SR/MI Trace Continuity test passed (Record Resistance)	JF	
1.10 EHT/RTD's Released for Insulation	NA.	

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	2.2 GΩ (Passed/Fail):
	SR/MI @ 1000 VDC	2.2 GΩ (Passed/Fail): Pass
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
Jayfo	26/09/03	JF
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29103-ET-ST1203-1-3	EHT Controller #:	
Trace Part #:		Panel #:	
RTD'(s) #:		Circuit #:	
Trace Line #:		Rev #:	



1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required	NA	
1.2 EHT Tag Matches Part # and drawings	JE	
1.3 EHT is Routed and Installed as per specifications	JE	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	NA	
1.6 EHT/RTD's Tags are correctly labelled and installed	JE	
1.7 As-built drawings completed and submitted	NA	
1.8 Terminations are complete with correct wire tags	NA	
1.9 SR/MI Trace Continuity test passed (Record Resistance)	JE	
1.10 EHT/RTD's Released for Insulation	NA	

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	2265 (Passed/Fail):
	SR/MI @ 1000 VDC	2.2652 (Passed/Fail): Pass
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
	26/09/03	
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0



CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29103-ET-ST1103-1-3	EHT Controller #:	
Trace Part #:		Panel #:	
RTD(s) #:		Circuit #:	
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required	NA	
1.2 EHT Tag Matches Part # and drawings	JE	
1.3 EHT is Routed and Installed as per specifications	JE	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	NA	
1.6 EHT/RTD's Tags are correctly labelled and installed	JE	
1.7 As-built drawings completed and submitted	NA	
1.8 Terminations are complete with correct wire tags	NA	
1.9 SR/MI Trace Continuity test passed (Record Resistance)	JE	
1.10 EHT/RTD's Released for Insulation	NA	

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	2.2 GJR (Passed/Fail): Pass
	SR/MI @ 1000 VDC	2.2 GJR (Passed/Fail): Pass
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
	26/09/03	
Client Representative	Date (yy/mm/dd)	Signature



EHT & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29103-ET-ST1703-1-3	EHT Controller #:	
Trace Part #:		Panel #:	
RTD'(s) #:		Circuit #:	
Trace Line #:		Rev #:	



1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required	N/A	Yes JF
1.2 EHT Tag Matches Part # and drawings	JF	
1.3 EHT is Routed and Installed as per specifications	JF	
1.4 RTD's Receiving Report has been Completed if required	N/A	
1.5 RTD's are installed as per drawing and specification	N/A	
1.6 EHT/RTD's Tags are correctly labelled and installed	JF	
1.7 —As-built drawings completed and submitted	NA	
1.8 Terminations are complete with correct wire tags	NA	Not Termined / No Core markers
1.9 SR/MI Trace Continuity test passed (Record Resistance)	JF	
1.10 EHT/RTD's Released for Insulation	N/A	

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	(Passed/Fail):
	SR/MI @ 1000 VDC	(Passed/Fail): Pass
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
	26/09/03	
Client Representative	Date (yy/mm/dd)	Signature



EHF & RTD PRE-INSULATION INSTALLATION REPORT

YCQE-EHT-004 Rev.0

COOEC
CANADA COMPANY LTD.

CUSTOMER NAME: COOEC Canada Ltd.

PROJECT NAME: K1B Well Pad Project

CONTRACT#: CA23007-SCM-AGC-004

LOCATION: Module Yard

TRACE DATA

Trace #:	29103-ET-ST1603-1-3	EHT Controller #:	
Trace Part #:		Panel #:	
RTD'(s) #:		Circuit #:	
Trace Line #:		Rev #:	

1.0 PRE-INSULATION INSPECTION

	Results (Initial/N/A)	Comments
1.1 EHT Receiving Report has been Completed if required	NA	
1.2 EHT Tag Matches Part # and drawings	IF	
1.3 EHT is Routed and Installed as per specifications	IF	
1.4 RTD's Receiving Report has been Completed if required	NA	
1.5 RTD's are installed as per drawing and specification	NA	
1.6 EHT/RTD's Tags are correctly labelled and installed	IF	
1.7 As-built drawings completed and submitted	NA	
1.8 Terminations are complete with correct wire tags	NA	
1.9 SR/MI Trace Continuity test passed (Record Resistance)	IF	
1.10 EHT/RTD's Released for Insulation	NA.	

Insulation Testing Equipment

Test Equip. Model #	Test Equip. Serial #:	Cal. Due Date:
1.8 Pre-Insulation Insulation Test Results	SR/MI @ 500 VDC	(Passed/Fail):
	SR/MI @ 1000 VDC	(Passed/Fail): Pass
	SR/MI @ 2500 VDC	(Passed/Fail):

Comments:

Yanda Representative	Date (yy/mm/dd)	Signature
	26/09/03	
Client Representative	Date (yy/mm/dd)	Signature