



SMALL POWER AND CONTROL CABLE INSPECTION & TEST RECORD

COOEC
CANADA COMPANY LTD.

PART 1 – Project Description

Project: K1B Well Pad Project	Location:	Contract #: CA23007
----------------------------------	-----------	------------------------

PART 2 – Cable Description

Cable Tag Number: <u>24K2-VIA-002</u>	Cable Type: <u>Fieldbus</u>	System:
Cable Size: <u>1</u>	Conductors: <u>1</u>	Cable Voltage: <u>0.6/1</u>

PART 3 – Visual Inspection

	Initial /NA
1. Cable size, type, location, installation, and routing are in accordance with the drawings.(Check all connectors are tight)	<u>+</u>
2. Bend radius is in accordance with project specifications and the cable jacket is free of kinks.	<u>+</u>
3. Cable termination supports and support spacing is in accordance with drawings and project specifications.	<u>+</u>
4. Installation is neat and evenly spaced.(Junction boxes are cleaned out & wires are dressed within panduit)	<u>+</u>
5. Cable is free of surface damage.	
6. Correct cable tag is installed on both ends.	
7. Termination kit/materials are installed in accordance with the manufacturer's instructions.	<u>+</u>
8. Conductors are properly identified.(Core markers are the same font, size & evenly spaced / aligned)	<u>+</u>
9. Check phase location and marking (Left to Right, Top to Bottom, or Front to Rear) are in accordance with the drawings and project specifications.	
10. Insulation Test has been performed	
11. Enter all deficiencies and missing items on Form YCQE-PS-048 Rev.0	

PART 4 – Test Equipment

Make	Model	Asset/Serial Number	Calibrated On
------	-------	---------------------	---------------

PART 5 – Test Results

Insulation Resistance (Record Lowest Result)		Continuity (Record Highest Result)	
Test	Result	Test	Result
Conductor to Conductor	<u>1A</u>	Conductor to Cond	<u>1.0</u>
Conductor to Ground	<u>1A</u>	Conductor to Gro	<u>OL</u>
Conductor to Armour	<u>1A</u>	Conductor to Arm	<u>OL</u>

PART 6 – Remarks

PART 7 – Inspected/Approved By:

Yanda QA Representative: Name: <u>1</u> Date: _____ Signature: _____	Client Representative: Name: _____ Date: _____ Signature: _____
---	--

Form#: YCQE-E&I-113 Rev.0

Revision: 0

Rev. Date: July, 2026

Customer Ref#: