



Safety Spectrum London

# EMERGENCY LIGHTING PERIODIC INSPECTION AND TESTING CERTIFICATE



## DETAILS OF THE CLIENT

|          |                                                  |
|----------|--------------------------------------------------|
| Name:    | City Relay                                       |
| Address: | 1, 1 Townley Street and Elephant Houses SE17 1DX |

## PURPOSE OF CERTIFICATE

## EXTENT OF INSTALLATION COVERED BY THIS CERTIFICATE

|                                                             |     |                                                                         |
|-------------------------------------------------------------|-----|-------------------------------------------------------------------------|
| To certify continued compliance of an existing installation | N/A | 7x Emergency Lights Tested<br>ALL the Emergency Lights are working fine |
|-------------------------------------------------------------|-----|-------------------------------------------------------------------------|

## ADDRESS OF THE EMERGENCY LIGHTING INSTALLATION

|          |                                                  |
|----------|--------------------------------------------------|
| Address: | 1, 1 Townley Street and Elephant Houses SE17 1DX |
|----------|--------------------------------------------------|

## CERTIFICATION

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                        |                                                                                                               |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|---------------------------------------------------------------------------------------------------------------|
| Trading Title                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | Safety Spectrum London                                 |                                                                                                               |
| Contractor responsible for carrying out the inspection and testing (address)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Safety Spectrum London<br>58A Tudor Road Hayes UB3 2QD |                                                                                                               |
| I / we* hereby certify that the emergency lighting system installation at the above premises has been inspected and tested by me/us* in accordance with the 'Results Schedule of items inspected and tested' on page 2, and to the best of my / our* knowledge and belief, the installation complies at the time of my/our* inspection and testing with the recommendations given in BS 5266-1: 2016 Emergency lighting Part 1: Code of practice for the emergency lighting of premises, BS EN 1838: 1999 / BS 5266-7: 1999 Lighting applications - Emergency lighting and BS EN 50172: As amended / BS 5266-8: 2As amended Emergency escape lighting systems , except as stated in section D. |                                                        |                                                                                                               |
| Name (capitals)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | Shashi Pal                                             | Inspectors Signature<br> |
| Date                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | 22/12/2025                                             |                                                                                                               |

## RELATED REFERENCE DOCUMENTS

|                                                                                                                               |     |
|-------------------------------------------------------------------------------------------------------------------------------|-----|
| Periodic Inspection Report No. and/or date of most recent, covering the existing emergency lighting installation - see Note 1 | N/A |
| Other documents (if any) please state                                                                                         |     |
| N/A                                                                                                                           |     |

## NEXT INSPECTION

|                                                                                                                                        |          |
|----------------------------------------------------------------------------------------------------------------------------------------|----------|
| Enter interval in accordance with Clause 7.2 of BS EN 50172: As amended / BS 5266-8: As amended                                        |          |
| I/We*, the person identified in C, RECOMMEND that this installation is further inspected and tested after an interval of not more than | 6 Months |

The wiring system of an existing emergency lighting system should have been periodically inspected and tested in accordance with BS 7671 and a Periodic Inspection Report issued. Where applicable and where available, the serial number and/or date of the most recent report should be recorded in the space provided.



| PURPOSE OF INSTALLED EMERGENCY LIGHTING SYSTEM |                           |                              |                              |
|------------------------------------------------|---------------------------|------------------------------|------------------------------|
| <input checked="" type="checkbox"/>            | Emergency escape lighting | <input type="checkbox"/> N/A | Standby lighting             |
| <input checked="" type="checkbox"/>            | Escape route lighting     | <input type="checkbox"/> N/A | Partial standby lighting     |
| <input type="checkbox"/> N/A                   | Open area lighting        | <input type="checkbox"/> N/A | High risk task area lighting |

| EMERGENCY LIGHTING INSTALLATION ARRANGEMENT |                                    |                                     |                              |
|---------------------------------------------|------------------------------------|-------------------------------------|------------------------------|
| <input checked="" type="checkbox"/>         | Self-contained emergency luminaire | <input type="checkbox"/> N/A        | Standby generator system     |
| <input type="checkbox"/> N/A                | Central battery system             | <input checked="" type="checkbox"/> | Combined emergency luminaire |

| EMERGENCY LIGHTING INSTALLATION ARRANGEMENT |                  |                          |          |
|---------------------------------------------|------------------|--------------------------|----------|
| Type1                                       | Mode             | Facilities               | Duration |
| X self-contained                            | 0 non-maintained | A: including test device | 3 Hours  |
| Type                                        | Mode             | Facilities               | Duration |
| N/A                                         | N/A              | N/A                      | N/A      |

| TEST INSTRUMENT USED                                                                                 |             |                             |           |
|------------------------------------------------------------------------------------------------------|-------------|-----------------------------|-----------|
| Instrument 1 (light meter) Model                                                                     | Serial No   | Instrument 2 (if any) Model | Serial No |
| Megger                                                                                               | Megger 1750 | N/A                         | N/A       |
| Where periodic requirement P2 is carried out by measurement, details of instruments MUST be recorded |             |                             |           |



| RESULTS OF INSPECTION AND TESTING                                                                                             |                                                                                                                                                                                        |                   |                            |                        |
|-------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|----------------------------|------------------------|
| * Where "No" or "X" column is selected, the deviation must be recorded in<br>DETAILS OF DEVIATIONS FROM THE CURRENT STANDARDS |                                                                                                                                                                                        | System Conforms ✓ | *Does not conform: X or No | Not Applicable:<br>N/A |
|                                                                                                                               |                                                                                                                                                                                        |                   |                            |                        |
| BS 5266-1<br>clause<br>reference                                                                                              | REQUIREMENTS                                                                                                                                                                           |                   |                            | System<br>Conforms     |
| 4.2                                                                                                                           | P1- Plans are available and correct                                                                                                                                                    |                   |                            | ✓                      |
| Clause 6                                                                                                                      | P2- Under test conditions, adequate **illumination provided for safe movement on the escape route and open areas                                                                       |                   |                            | ✓                      |
| 6.3                                                                                                                           | P3- Luminaires correctly positioned and oriented as shown on plans                                                                                                                     |                   |                            | ✓                      |
| 6.3                                                                                                                           | Original design still valid                                                                                                                                                            |                   |                            | N/A                    |
| 6.6                                                                                                                           | P5- All escape route safety signs and fire fighting equipment location signs visible with the normal lighting extinguished                                                             |                   |                            | ✓                      |
| 7.8                                                                                                                           | P6- Correct application and siting of additional emergency lighting                                                                                                                    |                   |                            | N/A                    |
| 7.9                                                                                                                           | 7- Luminaires conform to BS EN 60598-2-22                                                                                                                                              |                   |                            | ✓                      |
| 9.1                                                                                                                           | P9- Wiring systems comply with the requirements if BS 7671                                                                                                                             |                   |                            | ✓                      |
| 9.2                                                                                                                           | P10- Fire protection of central wiring systems satisfactory                                                                                                                            |                   |                            | ✓                      |
| 9.2.5                                                                                                                         | P11- Emergency circuits correctly segregated from other supplies                                                                                                                       |                   |                            | ✓                      |
| 9.2.12                                                                                                                        | P12- Wiring to emergency lighting supply power sources a fixed installation, where a specialist plug and socket arrangement is used, it is protected against unauthorised interference |                   |                            | N/A                    |
| 9.3.3                                                                                                                         | P13- System has a suitable test facility for the application                                                                                                                           |                   |                            | ✓                      |
| 9.3.5                                                                                                                         | P14- Central power system output voltage range is compatible with the supply voltage range of the luminaires, taking into account supply cable voltage drop                            |                   |                            | ✓                      |
| 10.1                                                                                                                          | P15- Luminaires tested and found to operate for their full rated duration                                                                                                              |                   |                            | ✓                      |
| 11.6                                                                                                                          | P16- Operation and maintenance                                                                                                                                                         |                   |                            | ✓                      |
| 12                                                                                                                            | P17- Test records in the log book complete and satisfactory                                                                                                                            |                   |                            | N/A                    |
| 12.3                                                                                                                          | P18- Instructions together with a suitable log book showing a satisfactory commissioning test available for use by the building occupier                                               |                   |                            | N/A                    |
| 13                                                                                                                            | P19- Luminaires clean and undamaged with lamps in good condition                                                                                                                       |                   |                            | ✓                      |
| 13                                                                                                                            | P20- Building occupier and their staff trained on suitable maintenance, testing and operating procedures, or a current maintenance contract is in place                                |                   |                            | N/A                    |
| 13.2                                                                                                                          | P21- Evidence of servicing of Central Battery System (in line with manufacturer's procedures); in-house or current maintenance contract is in place                                    |                   |                            | N/A                    |
| 13.3                                                                                                                          | P22- Evidence of servicing of Standby Generator System (in line with manufacturer's procedures); in-house or current maintenance contract is in place                                  |                   |                            | N/A                    |
| 13.4                                                                                                                          | P23- After test, the charging indicators operate correctly                                                                                                                             |                   |                            | ✓                      |
|                                                                                                                               |                                                                                                                                                                                        |                   |                            |                        |
| Notes                                                                                                                         |                                                                                                                                                                                        |                   |                            |                        |
| 1 emergency light present in main entrance                                                                                    |                                                                                                                                                                                        |                   |                            |                        |
| 1 emergency light present in kitchen                                                                                          |                                                                                                                                                                                        |                   |                            |                        |
| 1 emergency light present in living area                                                                                      |                                                                                                                                                                                        |                   |                            |                        |
| 2 emergency lights present in second floor                                                                                    |                                                                                                                                                                                        |                   |                            |                        |
| 2 emergency lights present in third floor                                                                                     |                                                                                                                                                                                        |                   |                            |                        |



# NOTES FOR RECIPIENT

**THIS CERTIFICATE IS A VALUABLE DOCUMENT AND SHOULD BE RETAINED FOR FUTURE REFERENCE**

**This 'Emergency Lighting Periodic Inspection and Testing Certificate' consists of numbered pages. Any missing pages of this certificate would render the certificate invalid. If any of the boxes have been left blank without reasonable justification, you should ask the Contractor as to the reasons why**

**This certificate is to be issued only for the periodic inspection and testing of an existing emergency lighting installation to verify compliance of the installation to current standard BS 5266**

This certificate is been issued to provide evidence (along with the client's current 'Fire Risk Assessment'), to enable the Responsible Person or Competent Person acting on their behalf, (as required by the Management of Health and Safety at Work Regulations 1999 and the Regulatory reform (Fire Safety) Order 2005 in England and Wales) or The Employer or Other Persons who have duty over the premise to any extent and any person who through contract or tenancy have obligations in respect of maintenance or safety (as required by Fire (Scotland) Act 2005) or The Employer or Nominated Employee who has special responsibility for fire safety (as required by The Fire Precautions (Workplace) Regulations (Northern Ireland) 2001) and The Management of Health and Safety at Work regulations (Northern Ireland 2000), to continue to declare, the existing emergency lighting system has been inspected and tested in accordance with BS 5266 Emergency Lighting Part 1: 2016 Code of practice for the emergency lighting of premises, BS EN 1838: 1999/BS 6266-7: 1999 Lighting applications – Emergency lighting, and BS EN 50172: As amended/ BS 5266-8: As amended Emergency escape lighting systems, to verify that the emergency lighting installation continues to comply with these standards.

NOTE If you were the person ordering the work, but not the user of the installation, you should pass this certificate, immediately to the Responsible Person or Competent Person (England and Wales), Employer or Other Persons (Scotland) or the Employer or Nominated Employee (Northern Ireland) for the premises.

The certificate should be retained in a safe place and shown to any person inspecting or undertaking further work on the emergency lighting installation in the future. If you later vacate the property or building, this certificate will demonstrate to the new Responsible Person or Competent Person (England and Wales), Employer or Other Persons (Scotland) or the Employer or Nominated Employee (Northern Ireland) for the premises that the emergency lighting installation continues to comply with the requirements of BS 5266 Parts 1, 7 and 8 and with BS 7671 Requirements for Electrical Installations, at the time the certificate was issued (if accompanied with a current 'Periodic Inspection Report' on the electrical installation, as prescribed by BS 7671). If there is a change of use of the building or a change in occupancy, a new 'Fire Risk Assessment' should be carried out