

SINGLE-LINE DIAGRAM SCHEDULE - SUBSTATION-12

Drawing Reference: E-SLD-012-REV1 | Facility: Zone 12

Equipment Tag	Description / Function	Rating / Capacity	Protection Relay
XFRM-01	Step-Down Power Transformer Unit 1	25 MVA, 132kV/33kV	SEL-787 Differential
CB-132-B1	SF6 Main Circuit Breaker 1	1700A Continuous	SEL-751 Overcurrent
CB-132-C1	SF6 Main Circuit Breaker 2	1900A Continuous	SEL-751 Overcurrent

Total Operational Transformer Count for SUBSTATION-12: **1 units** rated at **25 MVA**.