

Ameya Agencies

Engineering & Fire Safety Solution



Off.: 215, Chhatrapati Nagar, Near M.S.E.B. Sub Station, Ring Road, NAGPUR -440015 Ph.: 0712-2250779

Cell: 08956623670, 09372072043, 09579285308 E-mail: contact@ameyafire.com, ameya_fire @yahoo.com Visit us at : www.ameyafire.com

License no-

Date-

12/11/2022

MFS - LA/RF-173 MFS - LA/RD-323 MFS - LA/RP-26

<u>Inspection Certificate of fire Prevention and Life Safety Measure</u> (FORM -B)

To, The Chief fire officer NMC, Nagpur

Certified that We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the Educational building of "Sanskar Vidya Sagar KDK College", Nandavan, Nagpur.

We further certify that these installations in the above mentioned Educational building are maintained in good repair and efficient conditions during the **period 1st July 2022 – 31st Dec 2022** as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah III of 2007).

The details of the inspection of installations carried out by us are mentioned in the report appended herewith.

Form B is issued only for the maintenance of fire work carried out in the above mention building it is not related with any construction their in

For, Ameya Agencies



SANSKAR VIDYA SAGAR

Mr Arvind Khobe

SANSKAR VIDYASAGAR
NANDANYAN NAGPUR-09
PRINCIPAL



Ameya Agencies

Engineering & Fire Safety Solution



Off.: 215, Chhatrapati Nagar, Near M.S.E.B. Sub Station, Ring Road, NAGPUR -440015 Ph.: 0712-2250779

Cell: 08956623670, 09372072043, 09579285308 E-mail: contact@ameyafire.com, ameya_fire @yahoo.com Visit us at: www.ameyafire.com

The details of the inspection of installations carried out by us

Sr.	Description	Qty	Work done	Remarks
no.				
1.	Fire hydrant system which included:- hydrant valve- 07 nos, Hose pipe-07 nos, Hose Box- 07 nos, Branch pipe-07 nos., etc	07 nos	Maintained, Checked & tested by us	All system is in working condition at the time of testing.
2.	Complete Hose Reel Drum with pipe	07 nos	Maintained, Checked & tested by us	All system is in working condition at the time of testing
3.	ABC type cap 5 kg – 06 nos.,	06 nos	Checked by us	All fire extinguisher is in working condition
4.	Fire Booster pump 900 LPM	01 nos	Maintained, Checked & tested by us	At the time of trail pump are working properly with the help of electric supply and with the help of generator
5.	Fire Inlet 2 Way	01 nos	Maintained, Checked & tested by us	All system is in working condition at the time of testing
6.	Fire Alarm System Including:- MCP (Manual Call Point) -08 nos, Electronic Hooter – 08 nos, 4 Zone fire Panel – 01 nos	08 nos	Maintained, Checked & tested by us	All system is in working condition at the time of testing

For, Ameya Agencies



Mr. Arvind khobe

SANSKAR VIDYA SAGAR

SANSKAR VIDYASAGAR NANDANVAN NAGPUR 09

PRINCIPAL



Ameya Agencies



Engineering & Fire Safety Solution

	Cell: 08956623670, 09372072043, 09579285				THE PARTY OF THE P		.com
	Following are the fir	e system con	nponents in	stalled for o	peration & mainte	nance	
	At:	: M/S Sanskar	Vidya Sagar.	Nandanyan, I	Vagnur		
		, 5 545	· / /	,			
Main Electrical Driven Pump				Booster Pump-		01 Nos	900 LPM
Underground Tank Capacity				Terrence Tank Capacity-		01 Nos	3000 lts
Control Panel				Fire Alarm Panel-		01 Nos	4 Zone
Net Riser Cum Down Comer				Brigade Inlet Valve-		01 Nos	2 Way
Diesel Gen	erator						
Sr.No.	Particular's	Ground	1st Floor	2nd Floor	3 rd Floor		Total
1	Floor Area(Sq. Mtr.)						
2	Landing Valve	1	2	2	2		07 Nos
3	Hose Pipe With Coupling 30 Meter	11	2	2	2		07 Nos
4	Hose Box	1	2	2	2	_	07 Nos
5	Branch Pipe	1	2	2	2		07 Nos
6	Hose Reel Drum With Shut Up Valve	1	2	2	2		07 Nos
7	Extinguisher ABC 5 Kg	2	2	1	1		06 Nos
8	Extinguisher CO2 4.5 Kg						
9	Extinguisher ABC 6 Kg						
11	Detector						
12	Manual Call Point	2	2	2	2		08 Nos
13	Hooter	2	2	2	2		08 Nos
14	Sprinkler						
10.4						1	

Licence

16

MFS - LA/ RF-173

MFS - LA/RD-323

MFS - LA/ RP-26

Place:

Nagpur

Date:

12-11-22

Yours Faithfully

For Ameya Agencies

SANSKAR VIDYA SAGAR

SANSKAR VIDYASAGAR NANDANYAN NAGPUR 09 PRINCIPAL