

# ASBESTOS REGISTER

**SITE:** 7515 Galea 6 Dudley Street, Randwick

**LAST UPDATED:** 31/05/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
27/01/2016	Front balcony	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
27/01/2016	External laundry	Asbestos cement ceiling lining	Non-friable	12 sqm	Good/stable	Remove and dispose of ACM as part of the contract works 6 sqm removed on 24/03/2017 6 sqm removed on 27/03/2017
27/01/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works