

ASBESTOS REGISTER

SITE: 7611 Humphreys.Payne 5/59 Gould Street, Bondi Beach

LAST UPDATED: 27/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
11/03/2015	Eave soffit lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works