

# ASBESTOS REGISTER

**SITE:** 7872      Brandon      Cremorne

**LAST UPDATED:** 11/09/2017

JOB NUMBER      CLIENT      ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
06/09/2017	Gable end cladding	Asbestos cement sheet	Non-friable	2.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
06/09/2017	Laundry wall lining	Asbestos cement sheet	Non-friable	4.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
06/09/2017	Ensuite wall lining	Asbestos cement sheet	Non-friable	2 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works