

ASBESTOS REGISTER

SITE: 7778 Shum 174 North Liverpool Road, Green Valley

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
01/09/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
01/09/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
01/09/2016	Bathroom	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
01/09/2016	WC	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
01/09/2016	Laundry	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works

ASBESTOS REGISTER

01/09/2016	Rear courtyard	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
01/09/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works