

ASBESTOS REGISTER

SITE: 7844 Connors 48 Cullen Street, Lane Cove West

LAST UPDATED: 07/09/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
04/09/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	18 sqm	Good/Stable Surface coated to the exposed areas	3 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
04/09/2017	Gable end cladding	Asbestos cement sheet	Non-friable	7 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works