

# ASBESTOS REGISTER

**SITE:** 7801 Soalheiro 65 Koorringal Avenue, Thornleigh

**LAST UPDATED:** 23/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
20/12/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	16.5sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works
20/12/2016	Laundry wall lining	Asbestos cement sheet	Non-friable	11.5sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works
20/12/2016	Bathroom	Asbestos cement sheet	Non-friable	12sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works
20/12/2016	Kitchen pantry	Asbestos cement sheet	Non-friable	5sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works
20/12/2016	Hallway cupboards	Asbestos cement sheet	Non-friable	6sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works

## ASBESTOS REGISTER

20/12/2016	Entry cupboard	Asbestos cement sheet	Non-friable	2sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works
20/12/2016	Shed	Asbestos cement sheet cladding	Non-friable	3.5sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works