

ASBESTOS REGISTER

SITE: 7692 Tanner 48 Mount Street, Coogee

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
14/12/2015	Cladding (framed walls of rear addition)	Asbestos cement sheet	Non-friable	19 sqm	Good/stable	Remove and dispose the ACM as part of the contract works
14/12/2015	Cladding (front gable cladding)	Asbestos cement sheet	Non-friable	10 sqm	Good/stable	Remove and dispose the ACM as part of the contract works
14/12/2015	Eave soffit lining (front gable soffits)	Asbestos cement sheet	Non-friable	2 sqm	Good/stable	Remove and dispose the ACM as part of the contract works
14/12/2015	Eave soffit lining (eaves of rear addition)	Asbestos cement sheet	Non-friable	7.2 sqm	Good/stable	Remove and dispose the ACM as part of the contract works
14/12/2015	Dining room	Asbestos cement sheet	Non-friable	19 sqm	Good/stable	Remove and dispose the ACM as part of the contract works