

ASBESTOS REGISTER

SITE: 7775 Howells.Byron 49 Young Street, Cremorne

LAST UPDATED: 22/05/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
06/09/2016	Sunroom	Asbestos cement sheet	Non-friable	4.5 sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the contract works 4.5 sqm removed 22/05/2017
06/09/2016	Laundry	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM sheeting from damage during the course of the works