

ASBESTOS REGISTER

SITE: 7759 Rowe 28A Sunbeam Avenue, Burwood

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
26/07/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
26/07/2016	Gable ends	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
26/07/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
26/07/2016	Playroom	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works