

ASBESTOS REGISTER

SITE: 7864 Pooley.Andrews 25 Thornton Street, Fairlight

LAST UPDATED: 30/10/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
25/10/2017	Electrical meter board	ACM	Non-friable	0.5 sqm	Good/Stable	Protect the retained ACM from damage during the course of the works