

ASBESTOS REGISTER

SITE: 7770 Field.Pinder 19 Morrice Street, Lane Cove

LAST UPDATED: 13/06/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
21/12/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	9.5 sqm	Good/stable Painted	5 sqm to be removed as part of the contract works. Protect the retained ACM from damage during the course of the works Removed 13/06/2017
21/12/2016	Garage ceiling lining	Asbestos cement sheet	Non-friable	10.5 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
21/12/2016	Under floor space	Asbestos cement sheet	Non-friable	0.5 sqm	Broken pieces	Remove and dispose of the ACM broken sheeting as required