

ASBESTOS REGISTER

SITE: 7822 Lyras 57 Universal Avenue, Georges Hall

LAST UPDATED: 01/05/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
28/04/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	21.6 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
28/04/2017	Gable end cladding	Asbestos cement sheet	Non-friable	4.5 sqm	Good/stable Painted	1.5 sqm to be removed as part of the contract works. Protect the retained ACM from damage as part of the contract works
28/04/2017	Rear deck privacy screen	Asbestos cement weatherboards	Non-friable	4 sqm	Good/stable Painted	Protect the retained ACM from damage as part of the contract works
28/04/2017	Electrical meter board	ACM	Non-friable	0.25 sqm	Good/stable	Protect the retained ACM from damage as part of the contract works